



Electrical Certificate of Compliance

Electrical Safety Certificate

608808

www.evro.co.nz/cocesc.pdf

CUSTOMER COPY



Blue text = Certificate of Compliance,

Red text = Electrical Safety Certificate,

Green text = Required for both certificates

WORK TYPE

☐ Low-risk (Maintenance Replacement)☒ General☐ High-risk (Requires Inspection)Has the work been done in compliance with AS/NZS 3000 Part 1 ☐ or Part 2 ☒

Has the work been done in accordance with the certified design for the electrical installation

Does the work rely on any manufacturer's instructions and suppliers' declarations of conformity

Tested in accordance with AS/NZS 3000

The installation connected to the electricity supply is safe to use

The work done has not adversely affected any other part of the installation.

Other Standards used

Customer

ERIK JACOBSON

Site ref.

Address of installation

12C KENT ST WHANGARUA KAEO

Type of system the installation is safe to connect to

2 PHASE 230V MEN

Number of electrical installations safe to connect to electricity supply



Power outlets



Light fittings/control



HWC



Ranges

Date work done

Start

Finish

9-12-22

Description of work done and by whom / Work related to ESC

BATHROOM RCDs, FARTHING CHECKED
EXISTING SW/BP METER BOX, FARTRED
H/W CYLINDER AND BENCH TOP

HOUSE WIRERED IN 1998

99mJ

98mJ

Test Results

Visual Inspection

Polarity

Correct Circuit Connections

Insulation Resistance

RCD

OK

☒☒☒☒☒☒

Earth fault-loop Impedance

Other Electrical workers involved

full name

registration

date

Issuing Electrician

full name

JOHN ARCHER

registration

E14305

phone

027 218 7701

company

J L ARCHER ELECTRICAL

The work on this certificate has been done lawfully and safely, and the information on the certificate is correct

signed

date

9-12-22

CUSTOMER COPY