

2 March 2016

CRANCH, KATHLEEN MARGARET
19 MANSON STREET
GATE PA
TAURANGA 3112

Dear Sir/Madam

Pool Fencing Inspection - 19 MANSON STREET 06612 550 00

Further to a pool fencing inspection undertaken at the above property on 26/02/2016, we note that your pool fencing does not meet the requirements of the Fencing of Swimming Pools Act 1987, for the following reasons:

- There is a clothesline/children's play equipment etc. within the immediate pool area.
- The immediate pool area is not restricted to that area used in connection with the use of the pool.

As such, Council now advises that the above mentioned areas of non-compliance must be rectified and brought to a compliant standard, within 28 days of the date of this notice. Council's pool fencing compliance staff will undertake a further inspection after this 28 day period, to determine whether compliance has been achieved.

You do not need to be present at this re-inspection; however should you wish to be, please contact the undersigned to arrange a mutually convenient time and date. Please also contact the undersigned should you manage to achieve compliance in the meantime and require re-inspection before the expiry of 28 days. Once the re-inspection has been undertaken we will contact you to advise the outcome.

We anticipate and appreciate your full cooperation in this matter.

Yours sincerely



Neil Page
Pool Fencing Inspector, Environmental Services

Please note: Council hereby advises that until such time that your pool fencing achieves compliance, and at all times whilst it remains non-compliant, the water level in your pool must be reduced to a depth of 40cm (16 inches) or less, which effectively deems your pool exempt from compliance requirements, pursuant to S.5 of the Fencing of Swimming Pools Act 1987.