

73 Devon Street Lot 6 DPS 27087 Section Block

ROTORUA CITY COUNCIL

Drainage to sewer
2110



Owner: Steward

Valuation No.: 652/659

Plumber:

Permit No.: 7458

Drainlayer: B. Garratt

Appn No.: 5935

INSPECTIONS

Date

4-8-76

*Drainage Tested
Existing drains Tested OK.*





5935

CITY OF ROTORUA

Valuation No. 652/659

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1959 at premises situated at:

Address 73 Devon St.

Legal Description:

Lot No. 6 Deposited Plan No. 27087

Section No. Block No.

Description of Work:

Existing Drains To Sewer

Name and address of Person for whom work is to be carried out: Stewart 73 Devon St.

Name and address of Registered Plumber:

Name and address of Registered Drainlayer: T. J. Smith 80 Whitworth St

Signature: T. J. Smith Date: 5-8-76

	VALUE	FEE
Plumbing	\$:	\$:
Drainage	\$ 150.00	\$ 7.00
TOTAL FEES		\$ 3.00

See reverse for Fees and Notes.

FOR OFFICE USE ONLY

Date Received6-8-76

Fee Paid\$ 3.00 17559

Date Paid6-8-76

Issue Approved

Date Approved5-8-76

Permit No.7458

Date Issued9-8-76

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (including value of fittings)	
Dollars	Dollars
up to 100	1.50
101 - 200	3.00
201 - 400	6.00
401 - 600	8.00
601 - 800	10.00
801 - 1000	12.00
1001 - 1200	14.00
1201 - 1400	16.00
1401 - 1600	18.00
1601 - 1800	20.00
1801 - 2000	22.00

2001 and over, 1 dollar extra for every \$200 or part thereof in excess of 2000 dollars.

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

Drainage Work: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 5ft head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 5ft head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

Plumbing Work: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- When work is complete.

Plans of Drainage and Plumbing work:

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.


In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.

Plans MUST show figured dimensions
and distances from section boundaries

Rotorua City Council
DRAINAGE PLAN

NEW SEWERAGE DRAINS—RED
STORMWATER—DOTTED BLACK
OLD DRAINS—FULL BLACK

652/659



OWNER

Stewart

No.

73

STREET

Devon St.

LOT

6

SEC.

DB 27087

BL.

SIGNATURE

[Signature]

OF DRAINLAYER

DATE

10-8-76