



Compliance and Electrical Safety Certificate



Unique ID: 34185 RH
Number of Attachments: N/A

P O Box 9956, St Clair, Dunedin 9012
PH 03 456 4530 Email: laserdunedin@xtra.co.nz

This form has been designed to be used by licensed electrical workers to verify low installations or part installations that comply with Part 2 of AS/NZS 3000 and are safe to be connected to a 230/400 volt multiple earth neutral (MEN) system of electrical supply.

(1) Location of Installation

Address: 8 Morepork Lane, Waipori Falls, Outram, 9073

(2) Customer Information

Name: Mr N Fraei

Postal Address: 8 Morepork lane, Waipori Falls, Outram, 9073

Phone and Email: 022 1085 284

(3) Electrical Worker Information

Name: Ryan Haines Registration/Practising License Number: E243267

Name of person(s) being supervised: George Cameron

(4) Work Details

This work is (circle): **additions** ☒ alterations / new work

The prescribed electrical work is: ☒ High Risk ☐ General ☐ Low Risk ☐ The homeowner has undertaken part of the electrical installation.
(Please tick ✓ as appropriate)

Indicate the number of each
item installed or altered:

Number of lighting outlets:

Number of socket outlets:

Number of ranges:

Number of water heaters:

Description:

Upgraded switchboard, remade and protected main and garage earths, replaced mains entry box and tails, remade and protected cables around garage switchboard

Tick (✓) if work includes:

☐ Mains

☒ MEN switchboard closest to point of supply

☒ Main Earthing System

☐ Electric Lines

(5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation or part of the installation:

☐ has been installed in accordance with a certified design

Attached ☐ or Reference:

☒ has an earthing system that is correctly rated

☒ contains fittings which are safe to connect to a power supply

☐ relies on supplier's Declaration of Conformity

Attached ☐ or Reference:

☐ relies on manufacturer's instructions (attach or reference)

Attached ☐ or Reference:

☒ has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010

☒ is safe to connect

Tests Carried Out

	Electrical Worker	Inspector
Polarity (independent earth)	<input checked="" type="checkbox"/>	
Insulation resistance	<input checked="" type="checkbox"/>	
Earth continuity	<input checked="" type="checkbox"/>	
Bonding		
Other		

Electrical Workers Signature: Date: 25/03/2022

(6) Electrical Safety Certificate

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Name: Ryan Haines Registration/Practising License Number: E243267

Signature: Date: 25/03/2022

THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED

R.C.D.. 1	x1	x5	Ramp
	27	24	21

R.C.D.. 2	x1	x5	Ramp
	56	16	27

R.C.D.. 3	x1	x5	Ramp
	27	24	21

R.C.D.. 4	x1	x5	Ramp

MAIN EARTH CONDUCTOR	SIZE	OHMS
		0.2ohms
LOCATION :		

MAINS	SIZE	INSULATION TEST

EARTH LOOP IMPEDANCE TO BE NO GREATER THAN 0.5 OHMS	
POWER POINTS :	
RANGE :	
OTHER CIRCUITS:	
MAIN EARTH:	

NETWORK LOOP	.31ohms,
--------------	----------

EARTH LOOP	281ohms
------------	---------

POLARITY	
POWER POINTS :	
RANGE :	

POTENTIAL SHORT CIRCUIT CURRENT				
VISUAL				

NOTES/ADDITIONAL DESCRIPTION
