



Thread

Thread	Mail No	Type	Subject	From	Recipients	Status	Date
	FCCL-RQST-000157	Request	Building Consent (Foundation re-level) 34 Carters Road Aranui	Mr Patrick Clark - THE FLETCHER CONSTRUCTION COMPANY LIMITED	Application Admin - Christchurch City Council	Responded	09/01
	CCityC-TRANSMIT-015081	Transmittal	Re: Building Consent (Foundation re-level) 34 Carters Road Aranui	Application Admin - Christchurch City Council	Mr Patrick Clark - THE FLETCHER CONSTRUCTION COMPANY LIMITED	N/A	09/01
	FCCL-TRANSMIT-000367	Transmittal	Re: Building Consent (Foundation re-level) 34 Carters Road Aranui	Mr Patrick Clark - THE FLETCHER CONSTRUCTION COMPANY LIMITED	Application Admin - Christchurch City Council	N/A	09/01
	CCityC-TRANSMIT-015109	Transmittal	Fwd: Building Consent (Foundation re-level) 34 Carters Road Aranui	Allocating Officer - Christchurch City Council	Millie Blay - Christchurch City Council	N/A	10/01
	CCityC-ADVICE-009209	Advice	Re: Building Consent (Foundation re-level) 34 Carters Road Aranui	Millie Blay - Christchurch City Council	Mr Patrick Clark - THE FLETCHER CONSTRUCTION COMPANY LIMITED	N/A	11/01
	CCityC-ADVICE-009224	Advice	Re: Building Consent (Foundation re-level) 34 Carters Road Aranui	Application Admin - Christchurch City Council	Mr Patrick Clark - THE FLETCHER CONSTRUCTION COMPANY LIMITED	N/A	11/01
	CCityC-IntCorr-003048	Internal Correspondence	Re: Building Consent (Foundation re-level) 34 Carters Road Aranui	Millie Blay - Christchurch City Council	Application Admin - Christchurch City Council	N/A	21/01
	CCityC-TRANSMIT-015525	Transmittal	Re: Building Consent (Foundation re-level) 34 Carters Road Aranui	Application Admin - Christchurch City Council	Mr Patrick Clark - THE FLETCHER CONSTRUCTION COMPANY LIMITED	N/A	21/01

Reference No: FCCL-RQST-000157

Internal Correspondence**CCityC-IntCorr-003048**

To Application Admin - Christchurch City Council
From Millie Blay - Christchurch City Council
Sent Monday, 21 January 2013 9:29:12 AM NZDT (GMT +13:00)
Status N/A
Subject Re: Building Consent (Foundation re-level) 34 Carters Road Aranui

Hi Admin,

This BC is ready to be typed if you have time today.
ABA10121857. Thanks.

Kind regards,

Millie Blay**Building Consent Officer**
Building Operations Unit

DDI 03 941 5474

Web www.ccc.govt.nz**Christchurch City Council**Civic Offices, 53 Hereford Street, Christchurch
PO Box 73013, Christchurch, 8154

Please consider the environment before printing this email

From: A Admin
Sent: 11/01/2013 10:30:49 AM NZDT (GMT +13:00)
To: Patrick Clark
Cc: Millie Blay
Mail Number: CCityC-ADVICE-009224
Subject: Re: Building Consent (Foundation re-level) 34 Carters Road Aranui

Dear Patrick,

APPLICATION FOR BUILDING CONSENT**PROJECT NO: ABA10121857****SITE ADDRESS: 34 CARTERS ROAD****DESCRIPTION: DWELLING ALTERATION: PARTIAL UNDERPINNING PERIMETER FOUNDATIONS**

This Aconex message is to inform you that your consent application has been lodged and that your consent number for this project is ABA10121857.

This message has been sent to you as the applicant, and also to the owner where possible.

For any enquiries regarding your application, please use Aconex to contact us.

Kind regards,

Anne Edwards
EQ Administration Officer
Building Approvals 1
Customer and Business Support
DDI: 03 9415262
Email: anne.edwards@ccc.govt.nz
Web: www.ccc.govt.nz
Christchurch City Council
Civic Offices, 53 Hereford Street, Christchurch
PO Box 73013, Christchurch, 8154
Please consider the environment before printing this email

From: P Clark
Sent: 09/01/2013 3:16:41 PM NZDT (GMT +13:00)
To: Application Admin
Mail Number: FCCL-TRANSMIT-000367
Subject: Re: Building Consent (Foundation re-level) 34 Carters Road Aranui

Please find attached all doc's needed for a foundation re-level at 34 Carters Road ,Arauni Christchurch.
Regards
Patrick Clark EQR 0277024605
Thanks for your time.

From: A Admin
Sent: 09/01/2013 11:29:19 AM NZDT (GMT +13:00)
To: Patrick Clark
Mail Number: CCityC-TRANSMIT-015081
Subject: Re: Building Consent (Foundation re-level) 34 Carters Road Aranui

Dear Patrick

Thank you for your information. Attached are the requested empty file containers for your consent documentation to be uploaded into.
The instruction guide on how to apply for a consent in Build Express has been attached. Please click the PDF file icon and select open to view. The instructions on how to format your documents and submit your application are located on page seven and continue to page fifteen.

The following documents need to be uploaded:

- application— including correct application form, check sheet, certificate of title and any sale and purchase agreements, together with a Licensed Building Practitioner Designer statement, if the application is for restricted building work
- specifications
- plans
- supporting documents

Note: The compulsory file fields (when superseding a document) have been set up specifically for your building consent. Please do not change these as any changes may result in a delay in processing.

You may have noticed a change in the titles of the document placeholders. Please continue to upload your application documents to the appropriate placeholders.

Other points to note:

- Application forms must contain a signature.
- All specification documents (each section), as well as supporting documents and plans, are to be bookmarked to reduce administration charges.

[Please feel free to contact us via Aconex if you have any further enquiries.](#)

Kind regards,

Sandi Rhynd

Building Approvals Officer
Building Approvals Team 1

DDI03 941 8526
Emailsandi.rhynd@ccc.govt.nz
Webwww.ccc.govt.nz
Christchurch City Council

Civic Offices, 53 Hereford Street, Christchurch
PO Box 73013, Christchurch, 8154

Please consider the environment before printing this email

From: P Clark
Sent: 09/01/2013 10:51:11 AM NZDT (GMT +13:00)
To: Application Admin
Mail Number: FCCL-RQST-000157
Subject: Building Consent (Foundation re-level) 34 Carters Road Aranui

Address 34 Carters Road Aranui
Owner Details , Craig Williamson 021 2692394
Description of Work , Construction. Install jacking pads and jack off the existing concrete foundations wall back to level. Jack and pack internal piles.

There is a section of vaneer on the eastern side of the main entry that suffered in-plane displacement of approximately 4-5mm.

We recommend that this be replaced if it is particable to obtain matching bricks be realigned and mortor joints filled with epoxy

injection resin and the repointing to match the existing. Makr good damage to walls, landscaping and external concrete patios

from the re-levelling.

PMO Fletchers
Claim number 2011-042891
Type **Building Consent**

Refer To	Mail No	From	From Organization	Subject
----------	---------	------	-------------------	---------