


93264 071  
17-6-93



PLANS APPROVED SUBJECT TO ALL RE-  
QUIREMENTS OF THE BYLAWS AND  
HEALTH DEPT. BEING FULLY COMPLIED  
WITH.  
Date 17.6.93 Permit Number 93264  
Inspector Alexander CM



Site & Drainage Plan

Lot 36 DP 27272


885sqm Scale 1:100

**MICHAEL J. SKELTON**  
DRAUGHTING AND DESIGN

Job No. 11/93 Sht. 1




SECTION 1:20




(A)

ELEVATIONS 1:50




(B)

DETAIL A 1:20



SHAPED STUD or BLOCKS DYNABOLTED TO BLOCK WORK, WITH DPC UNDER FULL LENGTH STUD DOUBLE NAILED TO THEM.

FLOOR PLAN 1:50



- NOTES: 1. TOTAL FLOOR AREA IS 18.079 m<sup>2</sup>. VENTILATION IS .902 m<sup>2</sup> BEING 5% OF FLOOR AREA (NZBC G4) SKY DOME @ 200mm HIGH ALLOWS .480 m<sup>2</sup> THE 1200 x 200mm WINDOW ALLOWS .960 m<sup>2</sup> TOTAL VENTILATION GAINED - 1.44 m<sup>2</sup>.
2. NATURAL LIGHT ALLOWANCE IS 1.803 m<sup>2</sup> BEING 10% TOTAL FLOOR (NZBC G7) SKY DOME ALLOWS .36 m<sup>2</sup>. 1200 x 200 WINDOW ALLOWS .960 m<sup>2</sup>. EXISTING WINDOW ALLOWS .480 m<sup>2</sup> TOTAL = 1.800 m<sup>2</sup>.
3. THERE IS TO BE NO COOKING FACILITIES IN THE NEW ADDITIONS. WASH BASIN ONLY.
4. CONTRACTOR TO CHECK ALL MEASUREMENTS ON SITE BEFORE COMMENCEMENT OF WORK.
5. ALL WORK IS TO COMPLY WITH NZBC & THE APPROVED DOCUMENTS.