

6 Otonga Road Street Lot DPS Section Block

ROTORUA DISTRICT COUNCIL



BC

Sanitary Drainage to Sewer (5179)

2598 PD

Owner: Bell

Valuation No.: 658/210

Plumber:

Permit No.: 2598

Drainlayer: B. Garratt

Appn No.: 12261

INSPECTIONS

Date: 23/10/80

DATE

14-10-80

Drain Inspected & Tested ✓

1

Application No. 12261

ROTORUA DISTRICT COUNCIL

Valuation No. 658/210

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein, and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1978 at premises situated at:

Address 6 Otonga R

Legal Description:

Lot No. _____ Deposited Plan No. _____

Section No. _____ Block No. _____

Description of Work:

Existing Drains to Sewer
& Escalier

Name and address of person for whom work is to be carried out:

Bell 6 Otonga R

Name and address of Registered Plumber: _____

Name and address of Registered Drainlayer: B. J. M.Signature: B. J. M.Date: 20-10-80

	Value	Fees
Plumbing	\$:	\$:
Drainage	\$ <u>28.60</u>	\$ <u>10.00</u>
TOTAL FEES		\$ <u>10.00</u>

See reverse for Fees and Notes

FOR OFFICE USE ONLY

Receipt Number 1378Fee Paid 10-00Date Paid 23-10-80

Issue Approved _____

Date Approved _____

Permit No. 2598Date Issued 24-10-80

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (excluding value of fittings)

Value of Work	Permit Fee
Up to \$50	\$10
\$51 - \$100	\$15
\$101 - \$200	\$25
\$201 - \$300	\$30
\$301 - \$400	\$35
\$401 - \$500	\$40
\$501 - \$600	\$45
\$601 - \$700	\$50
\$701 - \$800	\$55
\$801 - \$900	\$60
\$901 - \$1000	\$65

\$1001 and over, \$5 extra for every \$200 or part thereof in excess of \$1000

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

DRAINAGE WORK: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 1.5m head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 1.5m head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

PLUMBING WORK: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing Work

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.

ROTORUA DISTRICT COUNCIL

APPLICATION FOR NEW SEWERAGE RETICULATION CONNECTION

APPLICATION NO.

5179

VALUATION NO.

658/210

I, Ben

of 20 Roswell Rd

(Postal Address)

hereby apply for permission to couple to the District Sewerage Scheme on my property being:

Lot No. _____ (D.P.S.) D.P. _____

Situated in 6 Otonga Rd Street, Road,

owned by me.

Signature of Applicant: Ben

Date: 20-10-8

FEES PAYABLE

4" Connection \$50.00

6" Connection - Cost + 10%. Minimum charge
with Application \$50.00

EXAMINED _____


DRAINAGE INSPECTOR

FEE PAID 50-00

RECEIPT NO. 1378

DATE: 23-10-80

DRAINAGE PLAN



EOP

OWNER 1122 LOT SEC. BL.
No. 6 STREET O Tonga Ro SIGNATURE [Signature]
OF DRAINLAYER [Signature] DATE 14-10-80