

16 Otongo Road

ROTORUA CITY COUNCIL Lot 41 DPS 27272

Septic tank & drainage for 2 home units

Owner: T. Emsley

Number:

Drainlayer: H.J. Stagg

Appn. No. 361 487/11

Valuation No.: 653/458


Permit No.: 2727

Paid 12-3-73

INSPECTIONS

Date

13-2-73 Draw Test & Ball units to be coupled to one tank.
15-2-73 Draw Tested Top Section. Plumbing trap waste & water
13-8-73 Both Flts occupied. Serial Inspection



653/458


9th February 1973

Mr H.J. Stagg,
257 Clayton Road,
ROTORUA.

XXXXXX

8.00

Lot 41
DPS 27272
Otongo Road



CITY OF ROTORUA

Appn 361

Valuation No.

487/1
653/458

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1959 at premises situated at:

Address Olunga Rd. Rotorua.

Legal Description:

Lot No. 41 Deposited Plan No. 27272

Section No. _____ Block No. _____

Description of Work: Septic Tanks & Sanitary Drainage
on J. Home Unit.

Name and address of Person for whom work is to be carried out:

J. Emery. 10 Peace St. Rotorua.

Name and address of Registered Plumber: _____

Name and address of Registered Drainlayer: B. J. Hagg

257 Chapelton Rd. Rotorua

PLUMBING		
DRAINAGE	\$500	50.
TOTAL	- - -	

Signature: B. J. Hagg

Date: 8-2-73

Value of Work including Materials:

Plumbing: \$ _____
Drainage: \$ _____
Total: \$ _____
Fee Enclosed: \$ _____

See reverse for Fees and Notes.

FOR OFFICE USE ONLY

Date Received 8-2-73

Fee Paid \$8-00 Rec 8555

Date Paid 12-2-73

Issue Approved [Signature]

Date Approved 8/2/73

Permit No. 2727

Date Issued 9-2-73

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (including value of fittings)

Dollars	Dollars
up to 100	1.50
101 - 200	3.00
201 - 400	6.00
401 - 600	8.00
601 - 800	10.00
801 - 1000	12.00
1001 - 1200	14.00
1201 - 1400	16.00
1401 - 1600	18.00
1601 - 1800	20.00
1801 - 2000	22.00

2001 and over, 1 dollar extra for every \$200 or part thereof in excess of 2000 dollars.

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

Drainage Work: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 5ft head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 5ft head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

Plumbing Work: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- When work is complete.

Plans of Drainage and Plumbing work:

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.

Plans MUST show figured dimensions
and distances from section boundaries


Rotorua City Council

DRAINAGE PLAN

NEW SEWERAGE DRAINS—RED
STORMWATER—DOTTED BLACK
OLD DRAINS—FULL BLACK

SCALE: IN. TO A FOOT

653/458



OWNER

No.

I.B. 30224

Document Set ID: 557497

Version: 1, Version Date: 16/02/2010

LOT

SEC.

BL

SIGNATURE

OF DRAINLAYER

DATE

J. K. M. G. J.
STREET Otanga Rd.

41

27272

H. J. M. G. J.

15-2-73