



RRD001PCZY

Document Number: **RDC-186495**

Date Registered: **21/04/2011**



BC#65805



S0859 #28





Electrical Certificate of Compliance

For a low voltage installation if prescribed electrical work has been done on any part of it and the prescribed electrical work involved placing, replacing or repositioning conductors or fittings attached to conductors.

ME 74078

No. of attachments:



To be completed whether or not an inspection is required.

CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of customer: JOHN PATTERSON Contact Ph No: 3473114

Address of installation: 32A NIHAU ST

Postal address of customer if different from above: 54 MATRIMONIAL AVE

DECLARATION OF CONFORMITY (Please tick appropriate boxes or attach the Declaration of Conformity from the installation designer)

I declare that the design of the installation or part- installation described below complies with:

- (a) either Part 2 of AS/NZS 3000:2007 ☒ or Part 1 of AS/NZS 3000:2007 and Regulation 59 ☐
(b) and is compatible with the following supply system: 230V/400V MEN ☒ or other system (attached) ☐

This declaration is issued by:

Name: _____ Date: _____ Signature: _____

WORK DETAILS

- Please tick as appropriate where work includes:
- | | | |
|------------------------------------|---|---|
| No. of lighting circuits <u>30</u> | Mains <input type="checkbox"/> | Electrical Lines <input type="checkbox"/> |
| No. of socket outlets <u>24</u> | Main earthing system <input type="checkbox"/> | |
| No. of fixed appliances <u>3</u> | MEN switchboard closest to the point of supply <input type="checkbox"/> | |
- Description of work carried out by the installer (or if multiple installers or homeowner please attach details of work done ☐)

WIDE OF COMPLETE NEW DWELLING.

CERTIFICATION OF WORK (Please tick appropriate boxes)

I am satisfied, and certify, that the work described was done in accordance with the Electricity Act 1992; and that the completed installation or part-installation on which the work was done is electrically safe.

- ☒ The work has been installed in accordance with the design detailed in the Declaration of Conformity described above
☒ The tests as required by the Electricity (Safety) Regulations 2010 have been satisfactorily completed (Results attached ☐)
☒ The installation has an earthing system that is correctly rated
☒ The fittings on which work has been done are safe to connect to a power supply (Supplier declaration of conformity attached ☐)
☒ The installation or part-installation is safe to connect to a power supply

Certifier details (This section must be completed)

Name: TONY FEEK Registration No: E19858
Company: HERMAN ELECTRIC Contact Ph No:
Date: 22/3/11 Signature:

Electrical Worker details (if not certifier)

Name: John Patterson Registration No: E 9758
Company: Contact Ph No: 0274751034
Date: 22-3-11 Signature:

Inspection details

Electrical work requiring Inspection by a registered electrical Inspector

- ☐ Mains work (Mains, MEN switchboards closest to the point of supply or main earthing systems)
☐ Medical ☐ High Voltage Work
☐ Mains parallel generation systems ☐ Hazardous ☐ Animal Stunning/Meat Conditioning
☐ Work carried out in accordance with Part 1 of AS/NZS 3000:2007

I have inspected as per the Electricity (Safety) Regulations 2010 the work described above, and certify it electrically safe.

Name: _____ Registration No: _____ Contact Ph No: _____
Date: _____ Signature: _____

How to use...

Certificates of Compliance

CUSTOMER INFORMATION

Please print clearly and press firmly. Please include:

- the customer's name,
- Address of the installation,
- Customer contact details (Telephone No., Postal Address, etc)

WORK DETAILS

The description needs to clearly define what work has been done and what you are certifying. Use the boxes (No. of socket outlets etc) to assist with the description.

If extra space is needed for the description use an extra sheet of paper or an attachment form (available from the EWRB bookshop and some COC resellers).

It is recommended that the results of tests (for insulation resistance, polarity, earth continuity etc) be recorded in this section.

CERTIFICATION OF WORK

Complete the "Electrical Worker Details" part in all cases. The "Certification of Electric Lines" part need only be completed where the worker installing electric lines is different to that carrying out other electrical work.

INSPECTION DETAILS

Where the work requires inspection (under 70, 71 and 72 of the Electricity (Safety) Regulations 2010) this section must be completed by the electrical inspector.

The electrical Inspector who inspects the prescribed electrical work is required to give a certificate of compliance to the owner/occupier of the fittings/premises within 20 working days.

WORKERS RESPONSIBILITIES

Electrical workers carrying out prescribed electrical work that involves the placing or positioning, or the replacing or repositioning of conductors (and fittings connected to those conductors), are required by law to ensure that:

- A Certificate of Compliance is completed for that work (Regulations 57, 58 and 59).
- Any work requiring inspection (Regulations 70, 71 and 72) is inspected and the appropriate section of the COC filled in by the electrical inspector.
- The relevant copy of the COC is given to the owner of the fittings or the occupier of the Premises within 20 working days of the works being completed (unless work requires inspection).
- A copy of the COC is retained for a minimum period of 3 years by the electrical worker completing the COC.

PARTIALLY COMPLETED ELECTRICAL WORK

If for any reason (e.g. a commercial dispute) a wiring job is left incomplete or unfinished a COC should be issued for the partially completed electrical work (Regulations 57, 58 and 59). Any work that may not be safe should be recorded in writing on a separate sheet and immediately handed to the customer. A copy can also be forwarded to the EWRB Registrar, PO Box 10156, Wellington.

Bc#65805.

