

170 Kawaha Point Road

DPS

Section

Block

ROTORUA CITY COUNCILPlumbing & Drainage to Dwelling
alterations

Owner: A.E. Beveridge

Plumber: Atkinson & Donaldson Ltd

Drainlayer: " " " "



BC

Valuation No.: 654/857/1

Permit No.: 4123

Appn No.: 1865

INSPECTIONS 4123


15-2-74

10 - Date 7/4

Plumbing Inspection. Drainage tested

22-14-74

Plumbing Inspection. Gas Inspection





Atkinson & Donaldson Ltd.

1865

CITY OF ROTORUA

Valuation No.

574/8 57/1

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK
I, the undersigned, hereby apply for permission to have the work described herein and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1959 at premises situated at:

Address Mrs R. E. Beveridge 170 Kawaha Point Road
Legal Description: (R.O.N. Section

Lot No. _____ Deposited Plan No. _____

Section No. _____ Block No. _____

Description of Work: Shifting of Existing Fittings installation
of W/C., Sanitary Unit, Hot and cold water
Drainage alterations, Shower to be installed

Name and address of Person for whom work is to be carried out:

Mrs. R. E. Beveridge 170 Kawaha Point

Name and address of Registered Plumber:

Atkinson & Donaldson Ltd.,
Box 576,

Name and address of Registered Drainlayer:

Rotorua.

PLUMBING	\$650-10-00
DRAINAGE	\$60-1-50
TOTAL	\$710-00

Value of Work including materials:

\$711-50

Plumbing: \$ _____
Drainage: \$ _____
Total: \$ _____
Fee Enclosed: \$ _____

See reverse for Fees and Notes.

Atkinson & Donaldson Ltd.

Signature:

Date:

J. Donaldson
12/21/74.

FOR OFFICE USE ONLY

Date Received _____
Fee Paid \$711-50 12/16/74
Date Paid 15-2-74
Issue Approved Ref
Date Approved 18/2/74
Permit No. 4123
Date Issued 13/2/74

FOR OFFICE USE ONLY

Atkinson & Donaldson Ltd.

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (including value of fittings)

Dollars	Dollars
up to 100	1.50
101 - 200	3.00
201 - 400	6.00
401 - 600	8.00
601 - 800	10.00
801 - 1000	12.00
1001 - 1200	14.00
1201 - 1400	16.00
1401 - 1600	18.00
1601 - 1800	20.00
1801 - 2000	22.00

2001 and over, 1 dollar extra for every \$200 or part thereof in excess of 2000 dollars.

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

Drainage Work: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 5ft head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 5ft head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

Plumbing Work: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing work:

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.

Plans MUST show figured dimensions
and distances from section boundaries

Rotorua City Council

DRAINAGE PLAN

SCALE: IN. TO A FOOT

NEW SEWERAGE DRAINS—RED

STORMWATER—DOTTED BLACK

OLD DRAINS—FULL BLACK

654/857/1

Atkinson & Donaldson Ltd.

EXISTING

3" P.V.C
JUNCTION
WITH C.EYE

3" P.V.C Vent

N/E EXISTING

3" P.V.C.

S.E.J.

2' 0" E G/T

S.E.J.

3' 6"

N/E (New)

New 4" DRAINAGE

SEPTIC TANK

45° cast bend.
S.E.

EXISTING
House

DRIVE

R.O.W. SECTION FROM KAWARA PT. ROAD FRONTAGE

New
DEM.

New PLASTIC
SWIM POOL

Atkinson & Donaldson Ltd.

OWNER Mrs. A. E. Beveridge

No. 170 STREET Kawara Pt.

LOT Atkinson & Donaldson Ltd.

SIGNATURE J. Donaldson

OF DRAINLAYER DATE 13/2/74