



INSPECTION REPORT

Name: **Jeffrey & Yvonne Neville**

Consent No: **BC170297**

Address: **392 Riwaka-Kaiteriteri Road, Kaiteriteri**

Inspected by: Richmond Grant

On **25/05/2017** at **2:29 p.m.** this site was inspected pursuant to the Building Act 2004 (section 222/230) and the Local Government Act 2004 (Section 174). The purpose of the inspection was:

26 FINAL INSPECTION: FIRE FREE-STANDING WHEN FREE-STANDING FIRE HAS BEEN COMPLETELY INSTALLED & SMOKE ALARMS FITTED

Notes Summary: Allan King has correctly installed Glen Dimplex Masport OSburn 1600 free standing woodburner , All clearances correct . 3 hush smoke detectors correctly fitted . sealed on roof . flue stays fitted . Fine to issue CCC .

Next Inspection: