

Don Thomson
Consulting Engineers

project name: 35-37 Johnston Street
part: IEP
job number: 213430

date: 30/09/2013
designer: RLM

Table IEP-4 Initial Evaluation Procedure Step 4

Building Name: Quest on Johnston
Location: 35-37 Johnston Street, Wellington

Step 4 - Percentage of New Building Standard

	Longitudinal	Transverse
4.1 Assessed Baseline (%NBS) _b	93%	93%
4.2 Performance Achieved Ratio (PAR)	1.0	1.0
4.3 Combination (PAR x %NBS) _b	93%	93%
4.4 Result	93%	

Step 5 - Potentially Earthquake Prone?

No

Step 6 - Potentially Earthquake Risk?

No

Step 7 - Grade

A

Relationship between Seismic Grade and %NBS

Grade	A+	A	B	C	D	E
%NBS	> 100	100 to 80	80 to 67	67 to 33	33 to 20	< 20