

20 Willow Ave Street Lot 29 DPS 33114 Section Block

ROTORUA DISTRICT COUNCIL



BC

Drainage to sewer (5457)

3216

Owner: T. Basfield

Valuation No.: 6993/618

Plumber:

Permit No.: 3216

Drainlayer: C. Fraser

Appn. No.: 378

INSPECTIONS

Date: 27/3/81

Date

27-3-81

Draw Test pvc. Old section completely replaced. Blocked & tested to bottom

Application No. 378

ROTORUA DISTRICT COUNCIL

Valuation No. 6993/618

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein, and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1978 at premises situated at:

Address 20 Willow AVE.

Legal Description:

Lot No. 29. Deposited Plan No. 33 114

Section No. Block No.

Description of Work: CONNECT EXISTING DRAINAGE TO SEWER

Name and address of person for whom work is to be carried out:
T BARFIELD 20 Willow AVE ROTORUA.

Name and address of Registered Plumber:

Name and address of Registered Drainlayer: COLIN FRASER 37 COLLIE DR. ROT.

	Value	Fees
Plumbing	\$:	\$:
Drainage	\$ 50 :00	\$ 10 :00
TOTAL FEES		\$ 10 :00

Signature: [Signature]
Date: 26/3/81

See reverse for Fees and Notes

FOR OFFICE USE ONLY

Receipt Number 2882

Fee Paid \$10

Date Paid 27-3-81

Issue Approved [Signature]

Date Approved [Signature] 27/3/81

Permit No. 3216

Date Issued

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (excluding value of fittings)		
Value of Work		Permit Fee
Up to	\$50	\$10
\$51 -	\$100	\$15
\$101 -	\$200	\$25
\$201 -	\$300	\$30
\$301 -	\$400	\$35
\$401 -	\$500	\$40
\$501 -	\$600	\$45
\$601 -	\$700	\$50
\$701 -	\$800	\$55
\$801 -	\$900	\$60
\$901 -	\$1000	\$65

\$1001 and over, \$5 extra for every \$200 or part thereof in excess of \$1000

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

DRAINAGE WORK: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 1.5m head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 1.5m head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

PLUMBING WORK: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing Work

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.

ROTORUA DISTRICT COUNCIL

APPLICATION FOR NEW SEWERAGE RETICULATION CONNECTION

APPLICATION NO.

5457

VALUATION NO.

6993/618.

I, T. BASFIELD.

of 20 WILLOW AVE ROT.

(Postal Address)

hereby apply for permission to couple to the District Sewerage Scheme on my property being:

Lot No. 29 (D.P.S.) D.P. 33114

Situated in 20 WILLOW AVE. Street, Road,

owned by me.

Signature of Applicant:

[Signature]

Date:

26/3/81

FEES PAYABLE

4" Connection \$50.00

6" Connection - Cost + 10%. Minimum charge

with Application \$50.00

EXAMINED

[Signature] 27/3/81

DRAINAGE INSPECTOR

FEE PAID

\$50.00

RECEIPT NO.

2882

DATE:

27-3-81


Plans MUST show dimensions and
distances from section boundaries in
metric units

Rotorua District Council

NEW SEWERAGE DRAINS — RED
STORMWATER — DOTTED BLACK
OLD DRAINS — FULL BLACK

DRAINAGE PLAN

Val No. 6993/618



Checked by *W. Coleman*
28.3.81

OWNER T. BASFIELD
No. 20 STREET WILLOW AVE

LOT _____ SEC. _____ BL. _____
SIGNATURE *[Signature]* DATE 28/3/81
OF DRAINLAYER