



INSPECTION REPORT

Name: **Hays Plumbing Services Limited**

Consent No: **BC145495**

Address: **43 Atkins Street, Motueka**

Inspected by: Glen Buckley

On **4/09/2014** at **5:12 p.m.** this site was inspected pursuant to the Building Act 2004 (section 222/230) and the Local Government Act 2004 (Section 174). The purpose of the inspection was:

25 FINAL INSPECTION: FIRE IN-BUILT WHEN IN-BUILT FIRE HAS BEEN COMPLETELY INSTALLED & SMOKE ALARMS FITTED

Notes Summary: The final inspection of the inbuilt fire has been completed. The fire has been installed correctly as to the Building Consent and specification on site. Smoke detectors fitted and tested. No wetback installed. Approved to light the fire. CCC Application received. Please Issue CCC

Next Inspection: N/A