



Private Bag RO 3029
Rotorua
New Zealand
Telephone (073) 484-199
Fax (073) 463-143

Address all
communications to:
District Manager
Rotorua District Council.

ENGINEERING

23rd MAY 91

P26-2-80

Please Quote
6550/992/46

LT169897AGW

S.A ROBSON
& L.A SHAW

3 AUGUSTUS EARLE PLACE
ROTORUA

Dear Sir/Madam



INFILTRATION PROGRAMME

Recently the Council completed an inspection of properties in your area as part of a programme to reduce the amount of stormwater entering the sewerage system.

During this exercise the following faults were found on your property at No 3 AUGUSTUS EARLE PLACE, Lot 46 D.P.S 43808

- ONE SEWERAGE GULLY TRAP IS
BELOW THE SURROUNDING SURFACE
LEVEL AT THE REAR OF THE HOUSE.

Would you please arrange for the necessary alterations to be made to comply with the Drainage and Plumbing Regulations 1978, by 28th JUNE 91, as follows :

- INSTALL ONE SEWERAGE GULLY TRAP
SURROUND TO A HEIGHT OF 75mm ABOVE THE
SURROUNDING SURFACE AND SEAL TO PREVENT
STORMWATER ENTERING THE GULLY TRAP.

If you have any queries or concerns please do not hesitate to contact Grant Williams at the Rotorua District Council.

Yours faithfully

A.G. Williams
Infiltration Technician Public Health

SISTER CITIES:
Klamath Falls, Oregon, U.S.A.
Beppu City, Oita, Japan.

FILE NOTE: P26280

3 AUGUSTUS EARLE PLACE ROTORUA

In reference to correspondence sent to property owner in regards to a drainage notice requesting repairs/modifications to gully trap surround.

I note that compliance has been met. Dated 27.3.95



M Browne
Asset Investigations Technician

FILE