

24 April 2009

P Bass
42 Madeleine Terrace
Papamoa 3118

Dear Sir/Madam

**Application for Building Consent Number 30115
Additional Information Required (Two Copies)**

Property Situated at: 179B Dickson Road
Lot No: 2 **DP No:** 74427

Two copies of the following information are required before your building consent application can be considered:

1. Your stringer fixing is still outside the scope of 3604. Also your bracing does not comply. Bracing for carports are not covered by 3604, therefore a specific design is required. You may need to speak with an engineer over your bracing requirements.

Yours faithfully

Mark Bell
For Building Services

Please address all Communications to:

Manager: Building Services
Tauranga City Council
Private Bag 12022
Tauranga

(Fax: (07) 577 7034)