



INSPECTION REPORT

Name: **R J Ker Contractors Ltd**

Consent No: **BC121096**

Address: **52/53 Parker Street, Motueka**

Inspected by: Richmond Grant

On **24/01/2013** at **2:42 p.m.** this site was inspected pursuant to the Building Act 2004 (section 222/230) and the Local Government Act 2004 (Section 174). The purpose of the inspection was:

29 FINAL INSPECTION: INTERIOR/EXTERIOR/CERTS CCC

Notes Summary: New unit built as per consented plans . all painting and decorating complete . Exterior roof and cladding secure and weather proof . water temperature checked 50C . 1 x smoke detector correctly fitted . Fire wall all correct , stopped and sealed . Fine to issue CCC

Next Inspection:

BC121096

29 FINAL INSPECTION: INTERIOR/EXTERIOR/CERTS CCC



BC121096

29 FINAL INSPECTION: INTERIOR/EXTERIOR/CERTS CCC



BC121096

29 FINAL INSPECTION: INTERIOR/EXTERIOR/CERTS CCC



BC121096

29 FINAL INSPECTION: INTERIOR/EXTERIOR/CERTS CCC

