

From: "Charles, Lawrence" <Lawrence.Charles@tetrattech.com>
Sent: Thu, 14 Nov 2024 15:47:59 +1300
To: "Myrtle Cantos" <Myrtle.Cantos@rotorualc.nz>
Cc: "Megan Pesefea" <Megan.Pesefea@rotorualc.nz>
Subject: RE: BC24-011274 - 13 Ross Road

Hello Myrtle,

Yes, this one is satisfactory.

I have left the following note as pile diagram was not exactly clear: ***Pile diameters are varied across the structure and deck. Please confirm correct diameters and depths during construction by a geo-professional.***

The amount charged on this one is per below.

BC Number	Amount Charged	15% GST	Total Amount Charged
BC24-011274	\$375	\$56.75	\$431.25

Cheers,
Lawrence

Lawrence Charles, BSc, MSc, CE (Calif), GE (Calif), CMEngNZ | Principal Geotechnical Engineer |
Geotechnical Manager - Rotorua
Direct +64 7 577 4281 | Business +64 7 571 6081 | Mobile +64 21 934 036 | lawrence.charles@tetrattech.com

From: Myrtle Cantos <Myrtle.Cantos@rotorualc.nz>
Sent: Thursday, November 14, 2024 2:35 PM
To: Charles, Lawrence <Lawrence.Charles@tetrattech.com>
Subject: BC24-011274 - 13 Ross Road
Importance: High

 **CAUTION:** This email originated from an external sender. Verify the source before opening links or attachments. 

Hi Lawrence,

Hope you are well.

Are you able to have a quick look on this BC before I send out my RFI.

This is currently on Day 8 😊

Thank you

Ngā mihi



Myrtle Cantos (BArch)

Pūkenga Whakaae Whare | Building Consents Assessor – Building Services

P: +64 7 351 8134

E: myrtle.cantos@rotorualc.nz

A: Civic Centre, 1061 Haupapa St, Private Bag 3029, Rotorua 3046, New Zealand

W: rotorualakescouncil.nz

