

2011/121



Waitaki District Council
20 Thames St
Private Bag 50058, Oamaru
Phone (03) 433 0300
Fax (03) 433 0358

Issued in respect of NZ Building Act 2004 Section 45(c)(e), 92 (1)(2)(4)

To: (Owner/Designer) G + J POTTER

Street Address 36 GORDON ST WESTON

Valuation Number:

	2	1	6	3	0
--	---	---	---	---	---

 /

2	1	3	0	0	
---	---	---	---	---	--

Issued By: (Name of Approved Person) R. TRUVER

Qualification: ☐ Craftsmen Plumber - License No: _____
☒ NZHHA member - Reg number 1206

☒ Installation of solid fuel heater ☐ Wet back connection / reconnection

☒ Model (describe) WOODSMAN TOTARA c/A insert

I, R. Telford 1206, being an Approved Heater Installer have completed the above work in accordance with the appliance manufacturers installation instructions, AS/NZS 2918 2001, and where applicable G12 NZ Building Code and AS/NZS 3500.4 2003. I understand that this declaration will be used by Council in deciding whether to issue a Code Compliance Certificate for a building consent relating to this work.

10/06/2011
Date

Company Name: 224 Thames St. P.O. Box 109, Oamaru
Contact : Phone No: Ph: 03-434 9872 Fax: 03-434 9873 E Mail :
Fax No:

Complies with air quality standards.....

Hearth size large enough.....

Flue height above roof correct plus roof penetrations sealed.....

Flue installed correctly – joints, double lined, restraints.....

Flue Heat shield fitted when required.....

Combustible wall distance meets requirements.....

Seismic restraint fitted.....

Smoke alarms within 3 mtrs any bedroom (hush facility).....

Chimney condition clean and sound (inbuilt).....

Heat shielding/ insulation fitted (inbuilt).....

Mantel deflector fitted where required (inbuilt).....

Tempering valve fitted (new wetback).....

Wetback open exhaust , pipe revolve copper, gradient, bends, and size and fittings comply.....

Condition of hot water cylinder checked and suitable to receive wetback.....