

APPROVED FOR C.C.C. / C.C.S. ISSUE

INCIL

B.C.O.

MAIN OFFICE

20 Thames Street, Oamaru

Telephone 0-3-434 1624

Facsimile 0-3-434 1611

WAIHEMO SERVICE CENTRE

54 Tiverton Street, Palmerston

Telephone 0-3-465 1106

Facsimile 0-3-465 1111

on 33 Building Act 1991.

6/12/02

DATE

22-4-04 201798

Book No.

9618

CONSENT ISSUED:

Applicants Name:

A. F. Kafter

Mailing Address:

3 Frame St

Telephone:

Oamaru
4272 464

Facsimile:

Owner Name:

A. F. Kafter

LEGAL DESCRIPTION

Valuation Roll Number:

26260/49000

Lot:

ADP 6363

DP:

Section:

Block:

Survey District:

Property Number:

Planning:

VALUE OF PROPOSED PROJECT

The estimated value (G.S.T. Inclusive):

\$ 1.600

CONSENT DEPOSIT DETAILS

Amount \$

Receipt No.

Date Received:

PROJECT LOCATION

Rapid/Street Number and Road/Street Name

No:

3

Street/Road:

Frame

Location/Township:

Oamaru

PROJECT

Description of proposed work and intended use(s) in detail:

Extension to Garage
General usage

DETAILS

INTENDED LIFE: - Indefinite but not less than 50 years

- Specified as years

50 yrs

Foundations Only

New or Relocated Building

Domestic Garage/Outbuildings

Alteration

No. of Dwelling Units

No. of Storeys

Size of Buildings (m²)

15.8

Demolition

Heater

Power

Being Stage

of

1

Stages.

BUILDER(S):

Address:

REGISTERED DRAINLAYER:

Address:

CRAFTSMAN PLUMBER:

Address:

OTHER/CERTIFIER:

Address:

Producer Statement YES/NO

Producer Statement YES/NO

Phone No:

Reg. No.:

Phone No.:

Reg. No.:

Phone No.:

Reg. No.:

Phone No.:

[] SITING

[] BC BEAMS

[] FIRE WALLS/PART.

[] PRE-LINING/FIRE PART.

[] FOUNDATIONS

[] COLUMNS

[] INSULATION

[] NAILING/LININGS

[] BOND BEAMS

[] FLOOR SLABS

[] BRICK VENEER

[] COMPLETION

INSPECTIONS

13-12-02 Foundation & slab prepared. DPM = mesh
in place. Note. DPM not taped at
joints. JMB

22-4-04 Plumbing work completed JMB