

177 Old Taupo Street Lot 11 DPS 5265 Section



BC

ROTORUA CITY COUNCIL

Sanitary Drainage to City Sewer (1209)

8596

Owner: R. Spence

Valuation No.: 657/313

Plumber:

Permit No.: 8596

Drainlayer: M. Holder

Appn No.: 7065

INSPECTIONS

Date: 17.6.77

Date

17.6.77

Drainage Inspector Giving drainage okay

New drainage inspected & tested

2nd

Entered on plan.



7065

CITY OF ROTORUA

Valuation No. 657/313

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK
I, the undersigned, hereby apply for permission to have the work described herein and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1959 at premises situated at:

Address 177 OLD TAUPU ROAD.

Legal Description:

Lot No. 11 Deposited Plan No. 5265.

Section No. _____ Block No. _____

Description of Work: Sewer Connection

Name and address of Person for whom work is to be carried out:

MR R. SPENCE.

Name and address of Registered Plumber: _____

Name and address of Registered Drainlayer: M. A. Holder.

56 Parawai Road Napagatah.

Signature: M. A. Holder.

Date: 17. 6. 77.

	VALUE	FEE
Plumbing	\$:	\$:
Drainage	\$ 300:	\$ 6 :00
TOTAL FEES		\$ 6 :00

See reverse for Fees and Notes.

FOR OFFICE USE ONLY

Date Received _____

Fee Paid \$6.00 20935

Date Paid 17.6.77

Issue Approved [Signature]

Date Approved 17/6/77

Permit No. 8596.

Date Issued _____

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (including value of fittings)

Dollars	Dollars
up to 100	1.50
101 - 200	3.00
201 - 400	6.00
401 - 600	8.00
601 - 800	10.00
801 - 1000	12.00
1001 - 1200	14.00
1201 - 1400	16.00
1401 - 1600	18.00
1601 - 1800	20.00
1801 - 2000	22.00

2001 and over, 1 dollar extra for every \$200 or part thereof in excess of 2000 dollars.

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

Drainage Work: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 5ft head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 5ft head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

Plumbing Work: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing work:

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.


Plans MUST show dimensions and distances from section boundaries in metric units

Rotorua City Council

DRAINAGE PLAN

NEW SEWERAGE DRAINS — RED
STORMWATER — DOTTED BLACK
OLD DRAINS — FULL BLACK

657/313



OWNER R.J. Spence LOT 11 SEC. BL.
No. 177 STREET OLD TAUPO RD. SIGNATURE Mark Holder DATE 17.6.77
OF DRAINLAYER

CITY OF ROTORUA

APPLICATION FOR NEW SEWERAGE RETICULATION CONNECTION

APPLICATION NO.

1209

VALUATION NO.

~~653/251~~

657/313

I We RAYMOND SPENCE & PHYLLIS SPENCE

of 177 OLD TAUPU Rd ROTORUA
(Postal Address)

hereby apply for permission to couple to the City
our
Sewerage Scheme on ~~my~~ property being:

Lot No. 11 (D.P.S.) D.P.

Section No. Block No.

Situated in: 177 OLD TAUPU Rd Street
us
owned by me and at present in the occupation of:

Signature of Applicant

Beuca

Date 25-12-1975

FEES PAYABLE

4" Connection \$70.00

3" 6" Connection \$70.00

3" Any additional costs charged out to applicant

FOR OFFICE USE ONLY

EXAMINED

McCoolman 17/6/77

DRAINAGE INSPECTOR

FEES PAID \$ 70-00

RECEIPT NO. 16930

DATE 25-2-75