

PLUMBERS, GASFITTERS AND DRAINLAYERS BOARD
GASFITTING CERTIFICATION CERTIFICATE
Certificate No **480207**
 9th Floor, 70 The Terrace
 PO Box 10655
WELLINGTON
 Tel 04 494 2970
 Fax 04 494 2975
 website www.pgdb.co.nz

 BJ GIBB ENTERPRISES LTD
 OAMARU CREEK RD
 RD 3D
 OAMARU 9492

 PLEASE RETAIN GAS CERTIFICATE
 WITH PROPERTY DOCUMENTS.

THANK - YOU.

(Box No's not acceptable)

(Number)

(Street name)

48 B

FERNBROOK ROAD

(Suburb)

OAMARU

(Town/City)

Consumer:

MR

(Title)

P

(Initials)

BISHOP

(Family/Business name)

DESCRIPTION OF GASFITTING TO WHICH THIS CERTIFICATE APPLIES

Appliance

Flue

Ventilation

Qty	Type	Location	Make/model	Input rate	Type	Location	Type	Location
1	HOB	KITCHEN	FISHERY PAYLER C5603	34.5	RANGE HOOD	ABOVE	Room AREA	
1	IB FIRE	ZERO BOX LOUNGE	RINNAI IB35ETR	33MJ	TWIN SWIM THERM RADI		Room AREA	
1	WATER HEATER	CEILING SPACE	RINNAI INTRA-MAT 26LT LPS	195	VERTICAL FLUE		CEILING SPACE VIA FLUE FROM OUTSIDE	

Registered Gasfitter/s Supervised by certifier

Name

Registration No

Name

Registration No

Certificate owner

Registration No

On behalf of

Address

(If other than certifying gasfitter)

Category

Type (Regulation 24(1))

- ☒
- Domestic
-
- ☐
- Commercial
-
- ☐
- Industrial
-
- ☐
- Temporary
-
- ☐
- Other

- ☒
- New
-
- ☐
- Addition,
- ☐
- Extension,
-
- ☐
- Replacement
-
- ☐
- Alteration
-
- ☐
- Repair following accident

Gas Type

☐ NG☒ LPG☐ TLP☐ BioName of Gas Supplier **ON GAS**

Pipework Installed

☒ YES☐ NO

(attach pipework diagram)

Test Results**Other Testing**

15 min Duration

Combustion

10 kPa Test pressure

☐ Yes ☐ No

0 kPa Loss / gain

Ventilation

2.75 kPa Working pressure

☐ Yes ☐ No

Test Date

26/10/08

I certify that :-

- ① All appliances and fittings worked on by me or by persons working under my supervision are safe and that all work carried out was in accordance with all applicable requirements of the Gas Act 1992 and Gas Regulations 1993 as amended.
- ② The gasfitting to which this certificate applies does not make other parts of the installation unsafe or otherwise non-compliant with the Gas Act 1992 and Gas Regulations 1993 as amended.
- ③ Gasfitting work to which this certificate applies
☐ does ☒ does not include work on an appliance or fitting imported or manufactured by a person for their own use.

Certifiers Name

BARRY GIBB

Address

3 DRD

OAMARU

Registration No

09096

Signature

B/GIBB

Date

27/10/08