

Construction Statement (PS3) – Pipework Testing

1. TO: Building Consent Authority

Issued

by: Craig Bell

(Name of Certifying Plumber, holding a current licence)

In respect of Building Consent Number: _____

ABA: _____

BCN240494

Made by (Building Consent

WPL-Carr & Hindley

Applicant): _____

At (Project

Address): _____

5 Nirmal Way Lemonwood

In relation to (Description of

Work): _____

Plumbing of new house

I have been engaged to undertake the plumbing work on the above approved building consent. I hereby certify that the work complies with the building consent and the NZ Building Code, and I have undertaken a pressure test for water tightness in accordance with:

☒ NZBC G12/AS1 7.5.1 (a),(b): By pressurising the pipework to 1500 kpa for a period of not less than 15 minutes for the hot and cold water supply and checking to see that there are no leaks; or

☐ NZBC G12/AS1 7.5.2, NZS 7643 section 9: By pressurising the upvc. pipework to 1.5 times the maximum working pressure for a period of not less than 15 minutes and checking that there are no leaks; or

☐ NZBC G12 VM1, AS/NZS 3500.1:2003: By pressurising the pipework to 1500 kpa for a period of not less than 30 minutes and checking to see that there are no leaks; or

By working pressure – only acceptable for solid/liquid fuel heater wet back connections and solar hot water systems pipework for a period of not less than 15 minutes and checking that there are no leaks.

For sanitary fixtures used for personal hygiene, I confirm that the anti-scold device has been set so as to not exceed:

45°C for early childhood centres, schools, old people's homes, institutions for people with psychiatric or physical disabilities, hospitals. (G12/AS1 6.14.1(a))

or

☒ 55°C for all other buildings. (G12/AS1 6.14.1(b))

And I believe on reasonable grounds that the pipework has passed that test.

All work complies with the NZBC

Building is connected to a site specific allocated water meter Water meter

serial number is: _____

Name: Craig BellRegistration Number: 14899Qualifications: Craftman plumberAddress: 51E Baranake Ave

Phone Number: HOME: _____

WORK: 021440451

MOBILE: _____

Fax: _____

Email: craig@data.co.nz

I hereby state that the work prescribed in this consent application has been carried out by me or my employee and that the employee holds:

(select one)

A current licence under part 2, subpart 1 of the Plumbers Gasfitters and Drainlayers Act 2006; or

Is an exempt trainee under Section 13 of the Plumbers Gasfitters and Drainlayers Act 2006 and the work done by that trainee is carried out in accordance with a limited certificate issued by the Board to the trainee under section 14 of the Act.

I also understand that the Local Authority in accepting this construction statement will be relying on it to issue the code compliance certificate at the completion of the building work.

Signed: Craig Bell