



INSPECTION REPORT

Name: **Orange Residential Homes Limited**

Consent No: **BC160489**

Address: **184 Horton Road, Tasman**

Inspected by: Bevan Barker

On **4/04/2017** at **3:31 p.m.** this site was inspected pursuant to the Building Act 2004 (section 222/230) and the Local Government Act 2004 (Section 174). The purpose of the inspection was:

16 WET AREA MEMBRANE (SHOWERS): PROPRIETARY WET AREA SHOWER/WALL MEMBRANE INSTALLATION BEFORE COVERING UP.

Notes Summary: Revised plan sheets and specs to come as membrane is not that consented. PS3 to come from installer.

Next Inspection:

Failed Inspection Points

Name of applicator

To come with PS3

Membrane as per consent

Membrane not as specified on the building consent. Please provide revised details and specs when applying for CCC