

13 June 2017

This Producer Statement of Construction Review GLP-01 has been issued by **Gary Stevens** to R Nicholls (Drainmax) in respect of the following project:

Project Description	On-site Wastewater & Land Application System
Street Address	184 Hortons Road, Tasman
Legal Description	Lot 2 DP 324764

Gary Stevens has been engaged by R Nicholls to provide design observation services in respect of clause/s G13 of the New Zealand Building Code and AS/NZS 1547:2012 for the building work described on the approved plans.

Based upon this review and information supplied by the contractor during the course of the works, I believe on reasonable grounds that all work as specified under the above building consent with respect to clause/s G13 of the Building Code has been completed to the extent required by that consent.



Gary Stevens Consultant

www.gsconsulting.co.nz

gary.gsconsulting@gmail.com

mobile 021-108-1391

Inspection Observations

This inspection observation sheet must accompany Producer Statement of Construction Review issued by Gary Stevens.

The following inspection observations were made in order to verify the work installed by R Nicholls.

Type	Comments
<i>Inspect Installation of Hynds Advanced Environmental Wastewater Treatment System</i>	Hynds WW system installed as per manufacturers requirements. R Nicholls to provide as-built drainage plan. The system was commissioned by R Nicholls.
<i>Inspect installation of pressure compensated drip-line irrigation system.</i>	Dripline irrigation installed as per design criteria. Slight adjustment made however setbacks compliant. Flush valves protected.
<i>Check operation & Maintenance schedule is appropriate for this system</i>	Operation and maintenance appropriate for this system. R Nicholls to be contracted for ongoing maintenance.

Photographs

