

- Ventilation heating

The house does not have a ventilation system or a heat pump, the kitchen rangehood is vented externally.


- Summary -

Current state is compliant and wired to the standard of its day.

If any alteration work is done in the future it is recommended to upgrade the outside cable running from the meter station to the switchboard up to current standards.

Kind regards

Jacques Lubbe

A handwritten signature in dark ink, appearing to read 'Jacques Lubbe', with a stylized flourish at the end.