

Rotorua District Council
RECEIVED 23 FEB 1994
REFERRED TO *Eg*
Anderson
COPY TO *Dylan*

FILE P00859
343274



18 February 1994

Please Quote: P00859 Z

WLT342861AGW

Messrs JRB Kingston & NL Rykers
c/- Mr Kingston
P O Box 6448
AUCKLAND

Dear Sirs,


RE: SEWER CONNECTIONS 96-100 PUKUATUA STREET


Council has a sewer main which runs along the back boundary of three properties, 96, 98 and 100 Pukuatua Street Rotorua, of which you are the owners. A recent camera survey of this sewerline revealed groundwater infiltration entering the sewer from connections to all three properties. At present only 96 Pukuatua Street has a building currently connected to the sewer.

To repair these faults it will be necessary for Council staff to enter your properties, excavate and then reinstate. If you have no objection would you please sign and date this letter before returning in the enclosed envelope. If no reply is received in 21 days of the date of this letter, Council will commence work assuming that you have no objection.

Should you have any queries or concerns, please do not hesitate to contact Grant Williams at the Rotorua District Council.

Yours faithfully


A.G. Williams
Asset Investigation Technician

Approved 22/2/94


INTERNAL MEMORANDUM

| |
|-------------------------------------|
| <input type="checkbox"/> |
| <input type="checkbox"/> |
| <input type="checkbox"/> |
| <input type="checkbox"/> |
| <input type="checkbox"/> |
| <input checked="" type="checkbox"/> |

Urgent
As requested
For your information
For your comment
Please file
Please telephone
Please action

FILE

File No. 6500/128
729
Date 4.10.94 731
POO-B-57
POO-B-58
POO-B-59

Subject

Disconnections./Demolition

To:

Murray Haycock.

94, 96, 100 Pukuatna Street.

The contractor would like these
properties disconnected from
water and sewer at your
earliest convenience
Fees have been paid.

ROTORUA
DISTRICT
COUNCIL

Signature

C. Almond

Designation

SBO