

SITE INSPECTION NOTICE

Consent No: **BC240953**
Applicant: **Walsh Carol Sheila**
Site Address: **71 Davis Road CUST**
Work Type: **MARQUEE 71 DAVIS ROAD CUST LOT 1 DP 570321**
Building Name:
Location within site:
Level Unit Number:
Building Category: **C01**
Email To:

Enquiries about this inspection may be directed to the inspector listed on this notice, or via the contact details listed in the header.

Please email any requested documentation and records of work to buildinginfo@wmk.govt.nz using BC240953 in the subject line.

Inspection Type: **Marquee final**
Inspection Outcome: **Pass**
Inspected By: **John Thornton - 021 543 919**
Inspection Date: **1 November 2024**

Passed Items

NOTE ONLY - HOW TO APPLY FOR CODE COMPLIANCE

Notes to Owner / Applicant / Agent

A Building Consent is not completed until it has been issued with a Code Compliance Certificate after a passed Final inspection. The owner or their agent is required to complete a separate application for the Code Compliance Certificate (Form 6) as soon as possible after the building work is completed. The application form to apply can be downloaded via the link below or call 03 311 8906 for further information. <https://www.waimakariri.govt.nz/building-services/building-services/building-consents/related-content/building-application-forms-and-fact-sheets>

General Items

Building, Multi-unit, Lot or Tenancy
Approved Building Consent on site

Inspection Items

Siting
Peg protection
Fire exits
Illuminated exit signage
Fire extinguishers
Appropriate WC facilities
Form 6 received

Siting comparative to plans.

***SEE BELOW.**

Fire exits x 2.

Exit signs x2 in place.

Fire extinguishers in place clearly marked

Portable as consent and house facilities

***SEE DOCUMENTATION REQUIRED**

ADDITIONAL ITEMS (as applicable)

Additional PASSED with Site Instructions (Directives to Complete)

***Please ensure protection from tripping/injury is installed at both corner guide ropes and peg locations**

Documentation

Application form for CCC (Form 6)

Status

Required