



Electrical inspection - 113 King Edward Street 7120

All sub circuits are TPS (Tough plastic sheath) cabling - industry standard
No original circuitry present.

Resettable type overload protection in outside meter box fuse panel located under external ramp

RCD (Residual Current device) fitted to circuits / electrical fixtures present in damp areas, such as the bathroom(s), laundry. Also includes an outdoor socket supplying the gas califont.

Visual inspection pass for main earth system, switchboard, hot water system, oven, light switches and fixtures and power outlets.

Elite Electrical Services Ltd

Kane McLeod

A handwritten signature in blue ink, appearing to be "Kane McLeod", written over a horizontal line.

13.10.2021