

PRESSURE TEST CERTIFICATE

Piped Services at Pre-line

Issued by: **Hays Plumbing Services Ltd**

Registration Number: **23431**

Date: **31/10/2014**

In respect to the following

Piped services installed in accordance with G12.AS1 or NZ/AUS3500.1 and 3

Property Owner : **Matthew & Ruth Galvin**

Installed at: (Property Address): **113 King Edward Street, Motueka**

Building Consent Number: **n/a**



Signature of Client / Builder

Signature: **Nick Mercer**

		TICK
POLYBUTYLENE	30 MINUTE TEST , 1500KPA (220PSI)	✓
	12HR TEST , 700 KPA, (150 PSI)	
FUSIOTHERM	TEST 3 X 30 MINUTE AT 20 BAR SEPARATE FUSIO TEST REPORT ATTACHED	
COPPER	30 MINUTE TEST 1500 KPA	
REHAU RAUTITAN	30 MINUTE TEST 1500 KPA	

FOR COUNCIL USE ONLY

Register Check

☐

Date _____

Inspector Name : _____ Signature: _____