


Construction statement Plumbing pressure test

All sections of this form must be completed

TO BE COMPLETED BY THE PLUMBER WHO COMPLETED THE WORK			
Name	S H Herman	Building consent number	BC230719
Company	S H Herman Ltd	Certifying plumber registration number	14484
Site address	24 Westmoor Boulevard		
Legal description	Lot 128 Westwood, Rolleston		
Description of plumbing work	New Dwelling Plumbing Work		
I have sighted the above building consent and read the attached conditions of consent, and confirm that the plumbing pipe work and fittings have been selected and constructed to comply with the consented plans. I confirm that I have personally tested the water supply system by the method indicated below: ☒ by pressuring the pipe work to 1500kPa for a period of not less than 15 minutes (NZBC G12/AS1 7.5.1) (AS3500.4, 11.3 for 30 minutes, AS3500.5, 2.23.1 for 30 minutes) for both hot and cold water and checking to see that there are no leaks ☐ by pressure testing the upvc cold water pipe to 1.5 times the maximum working pressure for a period of not less than 15 minutes and checking to see that there are no leaks (NZBC G12/AS1, NZS7643 9.3.2) ☐ by pressure testing the pipe work in accordance with the manufacturer's requirements (note most robust test must be used) Test report attached ☐ Yes ☒ No			
I understand that Council will rely upon this construction statement, for the purposes of establishing compliance with the above building consent.			
Signature			Date 5.12.23
Plumber contact details			
Address	736 Robinsons Road, RD 8 Chch	Postcode	
Company	S H Herman Ltd	Fax	
Email		Mobile	021 222 7479