



Compliance and Electrical Safety Certificate

This form has been issued by the Electrical Workers Registration Board



Unique ID: 24 Westmoor Blvd

This form has been designed to be used by licensed electrical workers to certify low voltage installations or part installations that comply with Part 2 of AS/NZS 3000 and are safe to be connected to a 230/400 volt multiple earth neutral (MEN) system of electrical supply.

(1) Location of installation

Address: 24 Westmoor Blvd Rolleston

(2) Customer Information

Name: Homes by Parklane Ltd

Postal Address: PO Box 11054 CCL

Phone and Email: 03343000

(3) Electrical Worker Information

Name: Julian Gabbie Registration/Practising Licence Number: E18975

Organisation: A Team Electrical Ltd Telephone Number: 021466587

Email: ateam@electricatwinowillive.com

Name of person(s) being supervised: Isaac Purnham / Ellen Gabbie

(4) Work Details

The work is (circle): ☐ Additions ☐ Alterations ☒ New work

The prescribed electrical work is: ☒ High Risk ☐ General ☐ Low Risk ☐ The homeowner has undertaken part of the electrical installation work.
(Please tick (✓) as appropriate)

Indicate the number of each item installed or altered

Number of lighting outlets: 24 1x formal hall

Number of socket outlets: 18 1x hall

Number of ranges: 1 1x bathroom heater

Number of water heaters: 1

Other Work?

Tick (✓) if work includes:

- ☒ Mains
- ☒ MEN switchboard closest to point of supply
- ☒ Main Earthing System
- ☒ Electric Lines

(5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- ☒ has been installed in accordance with a certified design
- ☒ has an earthing system that is correctly rated
- ☒ contains fittings which are safe to connect to a power supply
- ☒ relies on supplier's Declaration of Conformity (attach or reference)
- ☒ relies on manufacturer's instructions (attach or reference)
- ☒ has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010
- ☒ is safe to connect

Electronic reference: www.telherelectrical.co.nz

Electrical Worker's Signature: Julian Gabbie

Date: 19/12/24

If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declarations of conformity, provide a reference to where the documents can be found, in a readily accessible format, through electronic means.

Test Results

	Electrical Worker	Inspector
Polarity (Independent earth):	☒	
Insulation resistance:	<u>200 MΩ</u>	
Earth continuity:	<u>0.01 Ω</u>	
Bonding:	<u>0.01 Ω</u>	
Other (specify):		

(6) Electrical Safety Certificate

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use

Name: Julian Gabbie

Registration/Practising Licence Number: E18975

Signature: Julian Gabbie
(If certifier is different from electrical worker)

Date: 13/12/24