

File No:

P69084

CHECK LIST

FILE

3373010

**RESIDENTIAL SWIMMING POOLS**

OWNER'S NAME: MR. P. YEREX

ADDRESS: 15 CARTER DRIVE

LIC NO. 3844

INSPECTION DATE:

Complies.

VALUATION NO: 06562/861.00

	Complies	Non-complying	Comments
A. All fences shall extend a minimum of 1.2 above ground level on the outside of the fence.			
B. All fences shall be 1.2 metres above any permanent projection or permanent object located at ground level outside and within 1.2 metres of the fence.			
C. Where the fence is constructed of netting or mesh, any opening in the material greater than 10 mm, the fence will be required to be 1.8 metres in height.			
D. Where any netting or mesh is used no opening in the material is to be greater than 50 mm (no exemptions).			
E. Maximum clearance between the underside of any fence shall not exceed 100 mm.			
F. The fence must be durable and erected so as to inhibit any person from climbing over or under the fence.			
G. Where vertical pales or panels are used, spacings between each pale or panel shall be no greater than 100 mm.			
H. All support rails, rods wires bracing shall be on the inside of the fence "only" (no exemptions)			
I. All materials used in fence construction shall be firmly attached at the top and the bottom, to rails, pipe or similar structures so as to prevent access to the pool area by children under six years of age.			

GATES AND DOORS

A. All gates or doors entering a pool enclosure are required to open in an outward direction only?			
B. Be clear of any obstruction that could hold the gate or door in an open position.			
C. When lifted up or pulled down, the gate or door does not release the latching mechanism, come off its hinges or provide a ground clearance greater than 100 mm.			
D. All gates or doors are required to be fitted with a secure latching device.			
E. If the latching device is located on the inside of the fence or gate openable by either reaching over or through a hole in the fence the latch shall be at least 1.2 metre above ground level.			
F. If the latching device is outside the fence the latch shall be mounted no lower than 1.5 metres above ground level.			
G. Every gate is required to be fitted with an automatic closing device that will allow the gate to return to a fully close position, and latch from a distance no greater than 150 mm away from the closed and secured position.			

COMPLIES:Non-complying ☐

Inspected by: Checked by:

Paul Yerex

15 Carter Dr.

3488719

ne pool.
(all day)

ROTORUA DISTRICT COUNCIL

MS054981DJM

3363020

Received

File No. 656-534-14

Appln No. JED

NOTIFICATION OF EXISTENCE OF POOL

I, Paul Brian Yorex, as owner of the
(Owner)
property described below, hereby give notification of the existence of a
pool, as defined in the Fencing of Swimming Pools Act 1987.

Address: 15 Carter Dr.

Legal Description

Lot No. DPS

Section No. Block

Type of Pool Inground + spa

Signature of owner: P.B. Yorex

Address: 15 Carter Dr

Phone Number: 479944 H.
488719 B.

FOR OFFICE USE ONLY

Date of Notification:

Date of Inspection:

Inspection Remarks: complies JED 03:05:91