



5/179 Lake Road Mangakakahi,
Rotorua, New Zealand – 3015
TEL - 0800 345 388, 073453888

STATEMENT OF INSULATION

PROPERTY ADDRESS

47A Aquarius Drive Kawaha Point, Rotorua.

CEILING INSULATION

<u>EARTHWOOL GLASSWOOL R4.1</u>	<u>195 MM</u>	<u>YES</u>	<u>YES</u>
TYPE	DEPTH (mm)	Meets RTA standards	Meets HHS Insulation Standards

If Not able to Insulate, why? _____

UNDERFLOOR INSULATION

<u>MAMMOTH R1.5</u>	<u>100MM</u>	<u>YES</u>	<u>YES</u>
TYPE	DEPTH (mm)	Meets RTA standards	Meets HHS Insulation Standards

If Not able to Insulate, why? _____

GROUND VAPOUR BARRIER

INSTALLED: N/A THICKNESS: N/A

If Not able to Install, why? VENTILATED UNDERFLOOR, MEETS THE HEALTHY HOMES STANDARDS 2021

ASSESSOR: - CV SOHI

DATE: 22/02/2021

NOTES: -

THIS STATEMENT IS BASED ON THE OBSERVATIONS AND RECORDS COLLECTED ON THE DAY OF THE INSPECTION BY THE BAY ENERGY SOLUTIONS TEAM. INSULATION MATERIALS ARE NOT SECURE, AND CAN BE DISTURBED BY OTHER TRADES. NOTE - LEVEL OF WALL INSULATION CANNOT BE INSPECTED AND IS NOT COVERED BY THIS CERTIFICATE. HOWEVER, IT IS EXPECTED TO BE STATED IN TENANCY AGREEMENTS FROM JULY 2016

SITEWISE
GREEN > 2020/21

