



# Electrical Certificate of Compliance

for prescribed electrical work that is carried out on electrical installations and involves the placing or positioning or the replacing or repositioning of conductors (including fittings attached to those conductors).  
**To be completed whether or not an inspection is required.**

No. 1521191

No. of attachments 0

## CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of customer Generation Developments

Phone:

Address of installation Lot 51 Arlington Court Hamilton

Postal address of customer (if not as above)

## WORK DETAILS

29 No. of lighting outlets

1

No. of ranges

23 No. of socket outlets

1

No. of water heaters

Was any installation work carried out by the homeowner?

Yes

☒ No

Please tick (✓) as appropriate where work includes:

☒ Mains

☒ Main earthing system

☒ Switchboard

☐ Electric lines

Description New House, Main Earth  
Switch Board, Meter Board  
Internal Mains - 16mm<sup>2</sup> Twin TPS  
External Mains - 16mm<sup>2</sup> N/S TPS  
Laid as per AS/NZS 3000

It is recommended that test results be recorded here:

Visual Examination ☐

Earth Continuity ☐

Bonding ☐

Polarity ☐

Insulation Resistance \_\_\_\_\_ Mohm

Other \_\_\_\_\_

If necessary attach any pages with sketches of work done

## CERTIFICATION OF WORK

I certify that the above electrical work has been carried out in accordance with the requirements of the Electricity Act 1992 and Electricity Regulations 1997.

### ELECTRICAL WORKER DETAILS

Name

R BAKER

Registration no.

E16086

Company

GT ELECTRICAL

Signature

R Baker

Date

3-12-2003

Contact Ph No.

027 277 2424

### CERTIFICATION OF ELECTRIC LINES

(to be completed where a separate electrical worker has installed the electric line portion of the mains)

Name

Registration no.

Company

Signature

Date

Contact Ph No.

## INSPECTION DETAILS Electrical work requiring inspection by a registered electrical inspector

☒ New mains

☒ Switchboard

☒ Earthing system

Installation work in hazardous areas

I certify that the inspection has been carried out in accordance with the requirements of regulation 41 of the Electricity Regulations 1997.

Name

Gary Trotter

Registration no.

E2698

Signature

Gary Trotter

Date

3/12/03

Contact Ph No.

0274 867 667

**CUSTOMER COPY - THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED**