

Electrical Certificate of Compliance

for prescribed electrical work that is carried out on electrical installations and involves the placing or positioning or the replacing or repositioning of conductors (including fittings attached to those conductors).

To be completed whether or not an inspection is required.

No. 2089148

No. of attachments

CUSTOMER INFORMATION - PLEASE PRINT CLEARLY

Name of customer: Amyt Peter BlakePhone: 302 8461Address of installation: 26, Alford St, Methuen.

Postal address of customer (if not as above)

WORK DETAILS

13 No. of lighting outlets2 No. of ranges

Please tick (✓) as appropriate where work includes:

8 No. of socket outlets1 No. of water heaters☐ Mains☐ Main earthing system

Was any installation work carried out by the homeowner?

☐ Yes☒ No☒ Switchboard☐ Electric linesDescription: Re wire where requiredReplaced old Fuses & MCB bases. (except acc)Earth Rod installed & new Earth (main)Earth Bar installed @ DBNew Living circuits (replaced old)New Power circuits (replaced old)New water heater circuit.New Accessories where required

It is recommended that test results be recorded here:

Visual Examination



Earth Continuity



Bonding



Polarity

Insulation Resistance +200 MΩ Mohm

Other

If necessary attach any pages with sketches of work done

CERTIFICATION OF WORK

I certify that the above electrical work has been carried out in accordance with the requirements of the Electricity Act 1992 and Electricity Regulations 1997.

ELECTRICAL WORKER DETAILS

Name: Martin DodsonRegistration no.: E242896Company: Mike Pulley ElectricalSignature: M. A. DodsonDate: 25/01/07Contact Ph No.: 03 302 9207

CERTIFICATION OF ELECTRIC LINES

(to be completed where a separate electrical worker has installed the electric line portion of the mains)

Name

Registration no.

Company

Signature

Date

Contact Ph No.

INSPECTION DETAILS

 Electrical work requiring inspection by a registered electrical inspector☐ New mains☐ Switchboard☐ Earthing system☐ Installation work in hazardous areas

I certify that the inspection has been carried out in accordance with the requirements of regulation 41 of the Electricity Regulations 1997.

Name

Registration no.

Signature

Date

Contact Ph No.