



Tasman District Council

189 Queen Street, Richmond 7020

building.support@tasman.govt.nz

03 543 8400

BC180248

Alpha ID: 180248

Application Type: Building Consent

Site Address: 28A Poole Street, Motueka

Project Description: Install Masport freestanding wood burner

Project Status: Code Compliance Certificate Issued

Table of Contents

File Notes

File Notes Log	1
----------------	---

Blog ID: 75828**Author:** System**Created:** 2018-04-30 00:00:00

Notes: Fire Free-standing Final [Pass] Phillip Beck (BI) | 30 April 2018 - Monday
 SUMMARY: 26 Final Inspection: Fire Free-standing -- Free standing fire. Masport R1500 Ped installed to consent. Clearances comply. 1200mm flue shield fitted, seismic restraints fitted. One smoke detector in place. CCC application received. Please issue CCC.[Pass] Make and Model - Masport R1500P s/n 82687 — Phillip Beck (BI)[Pass] Hearth correct clearance — Phillip Beck (BI)[Pass] Masport — Phillip Beck (BI)[Not Applicable] Wetback installed by - plumber - None — Phillip Beck (BI)[Pass] Flue shield fitted - 1200mm — Phillip Beck (BI)[Pass] Inner flue secure in place and riveted SS — Phillip Beck (BI)[Pass] Framing in roof correct — Phillip Beck (BI)[Pass] Hush-type smoke detectors installed - One — Phillip Beck (BI)[Pass] Inspector completed a visual risk assessment for - Site safe — Phillip Beck (BI)

Blog ID: 131148**Author:** System**Created:** 2018-03-15 00:00:00

Notes: Migrated ES Notes:

NOTES FOR PROCESSOR: Original plans showed no doors or exists. Requested they be amended. Agent went into Motueka Service Centre and asked them to print off original floor plans and he marked the doors on that. It is a very poor copy, so all have been provided. James agreed they would be okay to process.

Noted By: Sally Blain | 2018-03-15

Blog ID: 179477**Author:** System**Created:** 2020-03-16 02:32:11

Notes: API added 'Project at End Other' block for the following reason: System set this project as

read-only as the project is at end.

Blog ID: 190277
Author: System
Created: 2020-04-25 03:21:14
Notes: Covid-19 Site Inspection Check

- If you are feeling unwell - do not attend site.
- Sanitise Hands
- Put on PPE
- Clean Equipment that is to be taken on site
- Upon Request Provide Site Manager with your Covid-19 Plan
- Sign the Site Register - All people entering the site must do this (tip - photograph site register)
- Complete Site Induction
- Follow Site Protocols maintaining Physical Distancing at all times
- While on site consider the Durability of Exposed Materials
- On completion Sign Out and Sanitise Hands
- Clean Equipment on completion of inspection
- To assist tracking Maintain a Record of Daily Contacts.

<https://www.building.govt.nz/covid-19/get-prepared-for-working-at-alert-level-3>

Blog ID: 315306
Author: System
Created: 2022-09-07 06:34:56
Notes: API removed 'Project at End Other' block for the following reason: Unarchived to recompile project documents (2022-09-07 06:34:56).
