



ELECTRICAL CERTIFICATE OF COMPLIANCE



REFERENCE/CERTIFICATE ID NO.: JB-2126C1	
This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.	
Location Details:	427 Armagh Street, Linwood, Christchurch, 8011
Contact name:	Crampton Smith
Contact phone:	
Contact email:	admin@cramptonandsmith.co.nz
Electrical worker details	
Name:	Blake Gorton-Quigley
Licence number:	E 004671
Phone:	+642102768869
Email:	blake@ampdelectrical.co.nz
Name and registration number of person(s) supervised:	
Certificate of Compliance	
The prescribed electrical work is:	High Risk
Type of work:	New work
- IF Prescribed work is HIGH - Please specify risk details: Mains 230 v men system	
Means of compliance:	Part 2 of AS/NZS 3000
Additional Standards or electrical code of practice were required:	No
- IF YES - please specify:	
Date or range of dates that prescribed electrical work undertaken:	02/04/2026 - 02/04/2026
Contains fittings that are safe to connect to a power supply?:	Yes
- IF YES - please specify system type: 230 v men system	
The installation has an earthing system that is correctly rated (where applicable):	Yes
Parts of the installation to which this certificate relates that are safe to connect to a power supply?:	Parts
- IF PARTS - please specify: Main switch Main neutral and main earth	
The work relies on manufacturers instructions:	No
If yes - identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)	
Identify:	
Link	
The work has been done in accordance with a certified design:	No
If yes - identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)	
Identify:	
Link	
The work relies on a Supplier Declaration of Conformity (SDoC):	No
If yes - identify the SDoC including name, date and version OR EECS registration. Also attach a copy of the SDoC to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)	
Identify:	
Link	
The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010:	Yes
Description of Work:	Replace mains entry box Replace switch board Replace main earth conductor New 6 mm for mains 1x 62 a main isolater and 1 x 63 a main switch
Test Results (provide values)	
Polarity (Independent earth):	0.02
Insulation resistance:	500 ohm Ohms
Earth Continuity:	Pas Ohms
Bonding:	Pass Ohms
Fault Loop impedance	Not applicable till living Ohms
Other (specify):	
By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.	
Date:	02/04/2026
Certifier's signature:	