

22 Allister Ave Street Lot 45 DPS 8048 Section Block

ROTORUA DISTRICT COUNCIL

Drainage to sewer (891C)

Owner: G. Tee

Valuation No.: 6997/633

Plumber:

Permit No.: 161

Drainlayer: D. Hunter

Appn. No.: 9624

INSPECTIONS


Date: 18/7/79

DATE

20.7.79

Checked - Tested

W. Phillips



Application No. 9624



ROTORUA DISTRICT COUNCIL

Valuation No. 6997/633

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein, and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1978 at premises situated at:

Address 22 ALLISTER AVE ROTORUA

Legal Description:

Lot No. 45 Deposited Plan No. 8048

Section No. Block No.

Description of Work: DRAINAGE SEWER Connection

Name and address of person for whom work is to be carried out:

GARY TEE 12A MOREY ST. ROTORUA

Name and address of Registered Plumber:

Name and address of Registered Drainlayer: D.D. Hunter 23 Kokei St.

	Value	Fees
Plumbing	\$:	\$:
Drainage	\$ 100 : 00	\$ 15.00
TOTAL FEES		\$:

Signature: Gary Tee

Date:

See reverse for Fees and Notes

FOR OFFICE USE ONLY

Receipt Number 187/79

Fee Paid 15-00 8069

Date Paid 18/7/79

Issue Approved [Signature]

Date Approved 17-7-79

Permit No. 161

Date Issued

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (excluding value of fittings)		
Value of Work		Permit Fee
Up to	\$50	\$10
\$51 -	\$100	\$15
\$101 -	\$200	\$25
\$201 -	\$300	\$30
\$301 -	\$400	\$35
\$401 -	\$500	\$40
\$501 -	\$600	\$45
\$601 -	\$700	\$50
\$701 -	\$800	\$55
\$801 -	\$900	\$60
\$901 -	\$1000	\$65

\$1001 and over, \$5 extra for every \$200 or part thereof in excess of \$1000

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

DRAINAGE WORK: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 1.5m head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 1.5m head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

PLUMBING WORK: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing Work

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.


Plans MUST show dimensions and distances from section boundaries in metric units

Rotorua City Council

DRAINAGE PLAN

Val No. 6997/633

NEW SEWERAGE DRAINS — RED
STORMWATER — DOTTED BLACK
OLD DRAINS — FULL BLACK



OWNER GARY TEE. LOT _____ SEC. _____ BL. _____
No. 12A STREET MOREY ST SIGNATURE Drainlayer DATE _____
22 Fluster Avenue

ROTORUA COUNTY COUNCILAPPLICATION TO CONNECT TO SANITARY SEWER.

I, G F Tee (Owners)
 WE, 14 Morey Street
 of Rotorua (Postal Address:
 hereby apply for a _____ diameter connection to the sanitary sewer
 from my/our property located in 22 Atastair Avenue Street/Road, bc
 Valuation Ref. 6997/633 Lot 45 D.P. 8048.
 Area : 0.928
 at present occupied by : _____

Signature of Applicant : _____ Date : _____

FEE PAYABLE

100 mm diam. (ordinary connection 1 per lot)	\$20.00
Each additional 100 mm ϕ connection	At cost, including s and administration charges.
150 mm diam.	At cost, including s and administration charges.

N.B. DRAINLAYER TO PROVIDE SITE DIAGRAM ON
REVERSE SIDE OF THIS FORM

FOR OFFICE USE ONLY

Connection Fee \$ 20 — paid Receipt No. 26732 Date 23/2/79

Rates Register entered _____ Date _____

DRAINLAYER : _____ D & P Permit No. _____

Tested by (Health/Drainage Inspector): _____

Date _____

Connection approved J. P. Philp

Connection date entered Rates Register _____ Date _____

Recorded on Plan No. _____ Draughtsman _____ Date _____