

MATAURA BOROUGH COUNCIL

(FORM 2)

FEE: 1050

PERMIT No. S 347

PERMIT FOR DRAINAGE WORK

REGULATION 87, DRAINAGE & PLUMBING REGULATIONS 1978.

(CONNECTION INTO SEPARATED SEWAGE RETICULATION SCHEME)

Mr K. Dunlop, plumber or drainlayer, is hereby authorised to carry out the work described herein as set forth in the plans deposited with me, on the premises owned or occupied by R. T. Gillies and situated at 40 River Street, Mataura, being Lot 2 Pt 1, DP 312, Town of Matakura.

Estimated value: \$ 200.00

Such work is to be carried out in strict accordance with the Drainage and Plumbing Regulations 1978.

CONDITIONS:

1. The Matakaura Borough Council office must be notified immediately the work is completed and ready for inspection, and no work may be covered over or filled in until it has been inspected and approved by the Borough Health Inspector.
2. Inspection/cleaning eye to be provided at the property boundary as detailed in the diagram below; such eye to be fitted with a cap or fitting sufficient to prevent the emission of odours from the reticulation system.
3. Such connection must be made within six months of the date hereunder, but in no circumstances shall the connection be made later than 31st August, 1987.
4. All stormwater shall be separated on the above described property and kept out of the foul sewerage system.

5. _____

Date: 28.4.88

M. J. Taylor
Town Clerk

FOR OFFICE USE ONLY

Date application received: 6/3/88


Index file noted: ✓

Numbers requiring attention: _____

Completed work inspected: ✓

As built plans received: ✓

Complete for filing: ✓



TYPICAL CLEANING EYE

APPLICATION FOR SANITARY DRAINAGE & PLUMBING PERMIT
(Drainage and Plumbing Regulations 1978 Reg. 6.1)

Received 30-50 Rec No 006270
Permit No. 347
Issued 28/4/88

Fees payable
Plumbing &
Drainage
Water connection
Sewerage connection
Street reinstatement

To the HEALTH INSPECTOR
Mataura Borough Council,
P.O. Box 14,
MATAURA.

Name R.J. Dunlop Plumber/Registered
Drainlayer

Full Postal Address P.O. Box 54
MATAURA

TOTAL \$

Value of Work Excluding Materials

Plumbing \$
Drainage \$ 200 - 00
Total \$ 200 - 00

N.B. ALL SECTIONS OF THIS APPLICATION MUST BE COMPLETED

Description of Property

Lot 21 Pt. 1
Section 1

D.P. 312
Block III TOWN OF MATAURA

Name and full postal address of property owner R.J. Dunlop
40 Rwei Street MATAURA

Utilisation No.
198

Registered Drainlayer R.J. Dunlop

Full description of work to be carried out

..... Sewer & Stormwater
..... Connections

Specifications of Materials

Wastes Traps Vents
Water Cold Water Drains
Effluent disposal system

Date 6-3-88

Signed R.J. Dunlop
Plumber/Registered Drainlayer

OFFICE USE ONLY

Conditions of Permit

- Plan is required
- Gully Trap - hatched
-

Date 8/3/88

M.B.C. had to
relocate the lateral
as it was 400 mm
deep. The plan
showed 1.1 metre

P.W. Tol Inspector

Application Approved Date 8/3/88

P.W. Tol Inspector

gross
incorrection
lateral
was
put in
7/3/88
R. O'Connor
3 hrs K. Dunlop
12 m pipe

00-920

DRAINAGE PERMITS & FEES (as from 1-10-87)

PERMIT FEES BASED ON LABOUR CONTENT OF WORK

Estimated value of labour involved	Fee
Not exceeding \$200	\$25.00
From \$201 - \$400	\$40.00
For each additional \$200 or part thereof ...	\$18.00

Water connection fee	\$ 50.00
Sewerage connection fee	\$ 75.00
Street reinstatement Gravel	\$35.00
Sealed	\$70.00

NEW SEWERAGE SCHEME

Drainage connection fee \$5.50

MATAURA.

SEWERAGE DIAGRAM

SCALE : 1 TO 100


SECTION NO. 40..... STREET RIVER..... OWNER MR. JACK GILLAN...

Note : The position of all water closets, urinals, sinks, downpipes traps etc, are to be shown on this plan.

Notes.

Mataura Borough Council had to relocate the lateral as it was only 0.4m deep. The plan said 1.1m.

Drawlayer: Ken Dunlop.



APPROVED : P. W. York..... HEALTH INSPECTOR DATE 2/3/88...