

Owners Name: <u>P & M K. F. F.</u>	Consent No. BC: <u>970404</u>
Project Address: <u>124 W. PLAKA ROAD</u>	Phone No.:
<u>Waverley</u>	Cell Phone No.:
Contact Person: <u>Owner</u>	
Date and Time of Inspection: <u>23/6/98</u>	
Request Taken by:	Date: Time:

Purpose of Inspection:	☐ Site/Pre Permit ☐ Footings/Foundation ☐ Floor Slab ☐ Blockwork ☐ Preline Building ☐ Other	☐ Preline Plumbing ☐ Insulation ☐ Drainage ☒ Completion Building ☐ Completion Plumbing
------------------------	--	--

Duration of Inspection:	 INSP
Building Control Officer Report:	
work of Rectification all completed OK ENTERED DSOF Date: <u>23/6/98</u>	
Building Control Officer: <u>DSOF</u>	Date: <u>23/6/98</u>

SOUTH TARANAKI DISTRICT COUNCIL

Ref: RD.26

Owners Name: M KIP Consent No. BC: 970404
 Project Address: 1 WERAORA Phone No.:
WATERLEY Cell Phone No.:
 Contact Person: PETER
 Date and Time of Inspection: 9/6/99
 Request Taken by: Date: Time:

Purpose of Inspection:

☐ Site/Pre Permit	☐ Preline Plumbing
☒ Footings/Foundation	☐ Insulation
☐ Floor Slab	☐ Drainage
☐ Blockwork	☐ Completion Building
☐ Preline Building	☐ Completion Plumbing
☐ Other	

Duration of Inspection:
 Building Control Officer Report:
FOOTING SOLID
OVER 900mm
IN DEPTH, STRINGER
COACH BOLTED IN PLACE
OK TO POUR
CONCRETE
 Building Control Officer: [Signature] Date:

SOUTH TARANAKI DISTRICT COUNCIL

Ref: RD.26

Owners Name: R & M KIFF Consent No. BC: 970404
Project Address: 124 WAIAPAOA Phone No.:
RD WAIRAKEA Cell Phone No.:
Contact Person: Owner
Date and Time of Inspection: 3/6/98
Request Taken by: Date: Time:

Purpose of Inspection: ☐ Site/Pre Permit ☐ Preline Plumbing
☐ Footings/Foundation ☐ Insulation
☐ Floor Slab ☐ Drainage
☐ Blockwork ☒ Completion Building
☐ Preline Building ☐ Completion Plumbing
☐ Other

Duration of Inspection:
Building Control Officer Report: JOIST FLANGES TO
BE INSTALLED TO RAFTERS
STEAMWATER TO BE REJECTED
TO SOAK 10/12
WHEN WORK BEING
PERFORMED INSPECTION
IS REQUIRED
05/6
Building Control Officer: Date: 3/6/98