

4 Pukeko

Street Lot

1

DPS

5422

Section

Block

ROTORUA CITY COUNCILDrainage to Sewer
1704

REG

Owner: E. Henderson

Valuation No.: 657/610

Plumber:

Permit No.: 6846

Drainlayer: H. Stagg

Appn No.: 5325


INSPECTIONS

Date

23.2.76

Drainage Inspected & tested. Existing drain okay
new Gully Summed fitted.
Jed





5325

CITY OF ROTORUA

Valuation No. 657/610

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK
I, the undersigned, hereby apply for permission to have the work described herein and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1959 at premises situated at:

Address 4 Pukeko.

Legal Description: 1
Lot No. 1 Deposited Plan No. S, 5422

Section No. Block No.

Description of Work: Connect plumbing to main sewer.

Name and address of Person for whom work is to be carried out: Mr. Menckman 4 Pukeko.

Name and address of Registered Plumber:

Name and address of Registered Drainlayer: H. Slagg 207 Le Roy Road.

	VALUE	FEE
Plumbing	\$:	\$:
Drainage	\$ 2.00:	\$ 3 :.00
TOTAL FEES		\$ 3 :.00.

Signature: H. J. Slagg
Date: 23/2/76.

See reverse for Fees and Notes.

FOR OFFICE USE ONLY

Date Received

Fee Paid \$3.00 15368

Date Paid 23.2.76

Issue Approved

Date Approved 23/2/76.

Permit No. 6846

Date Issued 24-2-76

FOR OFFICE USE ONLY

FEE PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (including value of fittings)

Dollars	Dollars
up to 100	1.50
101 - 200	3.00
201 - 400	6.00
401 - 600	8.00
601 - 800	10.00
801 - 1000	12.00
1001 - 1200	14.00
1201 - 1400	16.00
1401 - 1600	18.00
1601 - 1800	20.00
1801 - 2000	22.00

2001 and over, 1 dollar extra for every \$200 or part thereof in excess of 2000 dollars.

IMPORTANT

INSPECTION & TESTING REQUIREMENTS

Drainage Work: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 5ft head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 5ft head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

Plumbing Work: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing work:

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.