


New Foundation and Slab on the Ground.
 & New access ramp to sliding door.

*Note access to the disabled require ramp to
 a slope no greater than 1:12*

EXISTING HOUSE

NOTE
 On completion of building
 please notify the
 HURUNUI DISTRICT OFFICE
 P.O. Box 13 Amberley
 Ph (03)314 8816 Fax (03)314 8829

100mm concrete floor at 17.5 MPa ✓
 DPC Moistop or polythere 250 microns.
 Clean 30mm ^(20/40) tailings
 2 D12 Bolts with AL Links at
 600g to g ✓
 rods



HURUNUI DISTRICT OFFICE
 AMBERLEY PH. (03) 314 8816

24 HOURS NOTICE MUST BE GIVEN
 PRIOR TO FOUNDATION POUR,
 BLOCK FILLING AND FIXING OF
 INTERIOR LININGS.

BUILDING INSPECTOR

HURUNUI DISTRICT COUNCIL
 Plans and Specification APPROVED

In accordance with the Building Act 1991,
 clause 34(3) and the Building Regulations
 1992 clause 3.

Signed *[Signature]* (Building Official)











Dated 21/1/97

100x12m dynabolts to
 existing floor & foundation to tie
 new slab etc to house found. ✓

VISION

Conservatories

DESIGNER BUILT.



Wind Pressure (Pa)

HURUNUI DISTRICT COUNCIL


These plans and specifications must be read with the conditions attached to the Building Consent.



All construction work and materials used shall comply with the New Zealand Building Code, notwithstanding any inconsistencies which may occur in the drawings and specifications.



VISION ALUMINIUM LTD

49 TE RAMA PLACE WAINONI CHRISTCHURCH NEW ZEALAND
P.O. BOX 7354 TELEPHONE 811-315 FAX (04) 894 572.





HURUNUI DISTRICT COUNCIL

These plans and specifications must be read with the conditions attached to the Building Consent.

All construction work and materials used shall comply with the New Zealand Building Code, notwithstanding any inconsistencies which may occur in the drawings and specifications.