



Insulation Report

Property Address:

**41B Olliviers Road, Phillipstown, Christchurch 8011,
New Zealand**

Report Date:

Wednesday, May 13, 2026

Does insulation meet the minimum requirements for underfloor insulation in zone 3?

- **Yes**
- **All rooms have underfloor insulation in accessible areas.**
- **No gaps in insulation, other than clearances where required (e.g. professional installer cannot access due to height)**

When was the insulation installed:

11/05/2026

Type of Insulation:

- **Polyester Blanket**

R-Value or Thickness of the insulation:

- **R1.5**

Does the property have a moisture barrier installed?

- **Yes, installed to the NZS 4246 2016 building code.**
- **250 Microns**
- **Has a 150mm overlap or tapped all joins**
- **No gaps or holes**

Warming Houses into Homes www.ecohomeprogram.co.nz