

ROTORUA DISTRICT COUNCIL

Nº 136

Valuation No. 659/247
District Manager
Rotorua District Council
Private Bag
ROTORUA

Date: 29-4-86



P. Van der Molen
16 Willow Ave
Heldens Bay
Rotorua

Dear Sir,

DRAINAGE AND PLUMBING REGULATIONS 1978

An inspection of the drainage and/or plumbing work at the following premises was carried out
on 7-4-86 (date)

Owner: J. Klomp


Address: 14 Waiwaka Rd

Lot 35 D.P.S. 8661 Section

Block

The inspection revealed that the installation fails to conform to the provisions of the Drainage & Plumbing Regulations 1978 in the following respects:

Top W.C. Cistern has no overflow
discharging to outside wall



It will be necessary for you to alter the work so as to comply with the requirements of the Drainage & Plumbing Regulations within 7 days of the above date. Please advise me when the work has been completed, in order that a re-inspection may be undertaken.

Yours faithfully,

P. J. Concoran
PLUMBING & DRAINAGE INSPECTOR