



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE

REFERENCE/CERTIFICATE ID No.: **843 Donald Road**

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Location Details: 1843 Donald Road Maitland 9775

Contact Details: (Name and address) M&S Murrell As Above 0274815335

Name of Electrical worker: Matt Henson **Registration/Practising licence number:** E254056

Phone & email: matt.hens@icloud.com

Name and registration number of person(s) supervised:

Certificate of Compliance

Type of work: Addition Alteration New work
The prescribed electrical work is: Low risk General High-risk (Specify):

Switchboard

Means of compliance: Part 1 of AS/NZS 3000 Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required: No Yes (specify):

Date or range of dates that prescribed electrical work undertaken:

Contains fittings that are safe to connect to a power supply? Yes No

Specify type of supply system:

The installation has an earthing system that is correctly rated (where applicable) Yes No

Parts of the installation to which this certificate relates that are safe to connect to a power supply?

All Parts (specify) Replace steel conduit for tps to light circuits & upgrade circuit protection via mcb & rcds

The work relies on manufacturers instructions: Yes No

If yes – identify the instruction manual including name, date and version. Also attach a copy of manufacturer's instructions to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)

Identify: www.jarussell.co.nz
Link:

The work has been done in accordance with a certified design: Yes No

If yes – identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The work relies on a Supplier Declaration of Conformity (SDoC): Yes No

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)


Identify:
Link: www.ideal.co.nz

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010 No Yes

Description of Work:
Remove 2 x steel conduit light circuits and replace with tps cabling, make safe electrical connections in roof space and separate circuits via installing new mcb and rcd circuit protection at switchboard in store room.

| Test Results (provide values) | |
|-------------------------------|---|
| Polarity (Independent earth): | <input checked="" type="checkbox"/> |
| Insulation resistance: | <input checked="" type="checkbox"/> 7.1 Ohms |
| Earth Continuity: | <input checked="" type="checkbox"/> Ohms |
| Bonding: | <input checked="" type="checkbox"/> Ohms |
| Fault Loop impedance: | <input checked="" type="checkbox"/> 1.58 Ohms |
| Other (specify): | |


By signing this document I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.

Certifier's signature:  **Date:** 6/11/25

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifier's name: Matt Henson **Registration/Practising licence number:** E254056

Certifier's signature:  **Certificate Issue Date:** 6/11/25 **Connection Date:** 6/11/25

CUSTOMER COPY – THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS