

Date Inspected

12-1-89

Pile holes to deck and one side
of bed extension only. Excavation to
sizes as shown. Builders to level base
of holes prior to pour. Replace ribbon
joint with 50 mm timber to carry
joist hangers. #

CODE COMPLIANCE CERTIFICATE

Certifier	Signature	Date	Certifier	Signature	Date
BUILDING			POWER		
PLUMBING			GAS		
DRAINAGE			SERVICES		
E.H.O.			RESOURCE MGMT		
LIFTS			AIR COND.		
OTHER					

WORK IS NOW DEEMED TO BE COMPLETED. A CODE COMPLIANCE CERTIFICATE WILL BE ISSUED AS REQUIRED BY THE BUILDING ACT. CODE COMPLIANCE CERTIFICATE NO. _____

Signature_____
Designation_____
Date

WHEN THIS PROJECT IS COMPLETED THIS INSPECTION SHEET WILL BE ATTACHED TO THE RELEVANT PROPERTY FILE HELD AT THE COUNCIL OFFICE.

SPECIAL CONDITIONS: