

GASFITTING CERTIFICATE OF COMPLIANCE – GAS SAFETY CERTIFICATE



Client Name: Tracey Houston
Reference / Job #: ICP (if known):
Address of work: 8 Oconnell st
Suburb: Southbridge Town / City: Christchurch

Description of gasfitting work: (If different gasfitting work was done by different people, state who did what gasfitting.)

Run gas pipe work to rheem 27 test presure 3.18 kpa working presure 2.78kpa

Gas supply pressure 3.18 kPa Risk classification (tick one) ☐ Low-Risk ☒ General ☐ High-risk

Gas type (tick one) ☐ Natural gas ☒ LPG ☐ Biogas ☐ Other (specify)

The work has been done in accordance with a certified design: ☐ Yes ☒ No

☐ Copy of certified design attached (or provide reference)

The work relies on manufacturer's instructions:

☐ Yes ☒ No

☐ Copy of manufacturer's instructions attached (or provide reference)

The work has been done in accordance with means of compliance (specify):

☐ Yes – AS/NZS 5601.1 sections 3 to 6 ☒ Yes – AS/NZS 5601.2 sections 3 to 9 ☐ No

Were any other standards required for compliance?

☐ Yes (specify) ☒ No

Parts of the gas installation that are safe to connect to a gas supply?

☐ All ☒ Parts (specify)

Date(s) on which the work was done (if different from date of certifying gasfitting):

4.2.15

Name and registration number of anyone who carried out work under supervision:

☒ I confirm that I am satisfied that the work described in this certificate of compliance has been done lawfully and safely, and that the information on this certificate is correct.

Certifier name: graeme lackersteen

Registration number: 14191

Certifier Signature:

Date: 8/2/15

☒ I confirm that the work described in this Gas Safety Certificate, and the installation or part installation, is connected to a gas supply and is safe to use.

Name of person authorised to certify the connection:

GRAEME LACKERSTEEN

Registration number:

Date of completion or connection (if different from date of issuing GSC):

8/2/15

Certifier Signature:

Date:

This certificate confirms that the gasfitting work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.