
SITE INSPECTION NOTICE

Consent No: **BC180913**
Applicant: **Hudson Richard Nigel Durant**
Site Address: **55 Mandeville Park Dr MANDEVILLE NORTH**
Work Type: **GARAGE 55 MANDEVILLE PARK DRIVE MANDEVILLE NORTH LOT 27 DP 448155**
Building Name:
Location within site:
Level Unit Number:
Building Category: **R01**

Inspection Type: **Foundation & Floor Slab (Pre-Pour Single Pour)**
Inspection Outcome: **Pass**
Inspected By: **Lee Bithray - 027 434 5120**
Inspection Date: **27 September 2018**

Passed Items

General Items

Building, Multi-unit, Lot or Tenancy
Approved Building Consent on site

Inspection Items

Boundary peg locations and address/lot number	existing lot and dwelling
Confirm siting	Sited as plans
Finished floor level	
DPM	Black poly dpm lapped and taped
Foundation width and depth	
Reinforcing type, size, laps and spacing	D16 to perimeter on Chairs
Reinforcing cover	
Mesh reinforcing	665 mesh lapped tied and lifted
Check slab thickness	100 mm
Slab rebates	at garage door
OK to Pour	