

67 Leonard Rd Street Lot 66 DPS 26064 Section Block

ROTORUA DISTRICT COUNCIL

Pr D to new Dwg

Owner:

R. D. Wall.

Plumber:

B. Deba Huntu

Drainlayer:

MCB Irvine

fibra

28/11/83

INSPECTIONS

Valuation No.:

7067/225d

Permit No.:

8091 8090

Appn. No.:

5866 5867,

Date:

29-11-83

Date _____

30-1-83

17.484

Drainage defective Drainage PVC inspected. dwelling Relocated. from
Kamran. no water pipe installed as yet. all filling installed.
Plumber not fixed

Application No. 5866 5867.

ROTORUA DISTRICT COUNCIL

Valuation No. 7067/225pt

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein, and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1978 and Amendments at premises situated at:

Address 67 Leonard Rd NGO.

Legal Description:

Lot No. 66 Deposited Plan No. D D S 260 64

Section No. Block No.

Description of Work: Plumbing & Drainage for new dwelling.

Name and address of person for whom work is to be carried out:

R + S M Duffall
Name and address of Craftsman Plumber: B. De La Plante H1H3.
113 Rongitiro Drive Whakatane

Name and address of Registered Drainlayer: ~~Goodrich & Alding~~
McBurns Plumbing Co Rotorua
Hawera

	Value	Fees
Plumbing	\$1000.00	\$80 :
Drainage	\$800.00	\$68 :
TOTAL FEES		\$148 :00

Signature: [Signature]
Date: 4-11-83

See reverse for Fees and Notes

FOR OFFICE USE ONLY

FOR OFFICE USE ONLY	
Receipt Number	33
Fee Paid	148.00
Date Paid	29-11-83
Issue Approved	Raye
Date Approved	28-11-83
Permit No.	8691, 8692

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (excluding value of fittings)		
Value of Work		Permit Fee
Up to \$50		\$15
\$51 - \$100		\$20
\$101 - \$200		\$32
\$201 - \$300		\$38
\$301 - \$400		\$44
\$401 - \$500		\$50
\$501 - \$600		\$56
\$601 - \$700		\$62
\$701 - \$800		\$68
\$801 - \$900		\$75
\$901 - \$1000		\$80

\$1001 and over, \$7 extra for every \$200 or part thereof in excess of \$1000

IMPORTANT

INSPECTION AND TESTING REQUIREMENTS

DRAINAGE WORK: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 1.5 m head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 1.5 m head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

PLUMBING WORK: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

Plans of Drainage and Plumbing Work

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.


Plans **MUST** show dimensions and distances from section boundaries in metric units

Rotorua District Council

DRAINAGE PLAN

7067/225 PT.

NEW SEWERAGE DRAINS—RED
STORMWATER—DOTTED BLACK
OLD DRAINS—FULL BLACK



Landscape Drain.

LEONARD RD

OWNER DUFFALL

LOT 66 SEC. _____ BL. _____

No. 67 STREET LEONARD

SIGNATURE OF DRAINLAYER W. J. Turner DATE 30-11-83